


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 99.68 lm/W			
MODEL	LLS-BS3360FD1200	I _{max} (cd)	705.0	S/MH(C0/180)	1.19
NOMINAL POWER(W)	20	LOR(%)	100.0	S/MH(C90/270)	1.24
RATED VOLTAGE(V)	220	TOTAL FLUX(lm)	1936.8	h UP,DN(C0-180)	0.8,48.3
NOMINAL FLUX(lm)	1936.78	CIE CLASS	DIRECT	h UP,DN(C180-360)	0.7,50.2
LAMPS INSIDE	1	h up(%)	1.5	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	220	h down(%)	98.5	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2021-11-01

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


g	C0	C45	C90	C135	C180	C225	C270	C315	g	F zone	F total	%lum,lamp
10	681.3	685.5	686.3	689.9	696.1	692.6	687.8	683.4	0- 10	66.35	66.35	3.43,3.43
20	631.2	639.2	644.9	650.7	659.0	653.1	647.1	638.4	10- 20	188.9	255.3	13.2,13.2
30	559.0	570.3	579.7	586.7	595.6	589.5	583.0	569.7	20- 30	283.3	538.6	27.8,27.8
40	469.6	483.2	496.4	504.5	513.3	506.7	500.9	483.6	30- 40	337.0	875.5	45.2,45.2
50	368.1	380.8	399.3	407.3	416.6	409.5	401.6	383.7	40- 50	344.7	1220	63,63
60	257.2	272.2	292.3	299.0	306.2	301.8	293.6	275.1	50- 60	305.8	1526	78.8,78.8
70	140.9	158.4	176.8	186.0	192.6	185.9	179.5	159.7	60- 70	227.7	1754	90.6,90.6
80	40.22	54.36	68.56	76.23	82.77	75.89	70.52	55.58	70- 80	123.8	1878	96.9,96.9
90	4.069	4.051	2.188	4.630	6.574	3.507	0.8344	2.407	80- 90	30.13	1908	98.5,98.5
100	3.527	2.959	2.017	2.104	2.124	1.443	1.163	2.124	90-100	2.606	1910	98.6,98.6
110	3.893	3.384	3.096	2.661	2.339	2.161	2.773	2.668	100-110	2.573	1913	98.8,98.8
120	5.080	4.910	4.667	3.857	3.460	3.265	4.243	4.059	110-120	3.490	1916	98.9,98.9
130	6.484	6.012	5.790	4.944	4.750	4.461	5.460	5.403	120-130	4.316	1921	99.2,99.2
140	7.674	6.787	6.692	5.972	6.014	5.588	6.466	6.299	130-140	4.588	1925	99.4,99.4
150	8.610	7.341	7.817	7.035	6.967	6.785	7.336	6.898	140-150	4.307	1930	99.6,99.6
160	9.537	8.084	9.295	8.324	7.962	8.195	8.886	7.864	150-160	3.639	1933	99.8,99.8
170	10.37	9.768	10.52	9.907	8.650	9.630	10.21	9.703	160-170	2.586	1936	99.9,99.9
180	9.592	11.30	11.42	11.64	9.597	11.28	11.37	11.64	170-180	0.9760	1937	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2021-11-01

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:



LUMINANCE cd/(m2)		
G(DEG)	C0/180	C90/270
85	2319	7638
80	5849	9971
75	8485	11758
70	10400	13054
65	11862	14072
60	12989	14760
55	13812	15272
50	14462	15686
45	15005	16058


C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2021-11-01

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:

r _{cc}	80%			70%			50%			30%			10%			0
r _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.10	1.10	1.10	1.05	1.05	1.05	1.01	1.01	1.01	.98
1.0	1.04	.90	.96	1.02	.98	.94	.97	.94	.91	.93	.90	.88	.89	.87	.85	.83
2.0	.91	.84	.78	.89	.83	.77	.85	.80	.75	.81	.77	.73	.78	.75	.71	.69
3.0	.80	.72	.65	.78	.71	.65	.75	.68	.63	.72	.67	.62	.69	.65	.61	.58
4.0	.71	.62	.55	.69	.61	.55	.67	.60	.54	.64	.58	.53	.62	.57	.52	.50
5.0	.63	.54	.48	.62	.54	.47	.60	.52	.47	.58	.51	.46	.56	.50	.45	.43
6.0	.57	.48	.42	.56	.48	.41	.54	.47	.41	.52	.46	.40	.50	.45	.40	.38
7.0	.52	.43	.37	.51	.43	.37	.49	.42	.36	.48	.41	.36	.46	.40	.36	.34
8.0	.47	.39	.33	.46	.38	.33	.45	.38	.32	.44	.37	.32	.42	.36	.32	.30
9.0	.43	.35	.30	.43	.35	.29	.41	.34	.29	.40	.34	.29	.39	.33	.29	.27
10.0	.40	.32	.27	.39	.32	.27	.38	.31	.27	.37	.31	.26	.36	.30	.26	.24



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2021-11-01

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Wall Exitance Coefficients(WEC)															
0.0																
1.0	.302	.172	.054	.294	.168	.053	.280	.161	.051	.267	.154	.049	.255	.148	.048	
2.0	.285	.156	.048	.279	.154	.047	.266	.148	.046	.255	.143	.045	.244	.138	.044	
3.0	.265	.141	.042	.259	.139	.042	.248	.134	.041	.238	.130	.040	.229	.127	.039	
4.0	.245	.127	.037	.240	.126	.037	.230	.122	.036	.221	.119	.036	.213	.116	.035	
5.0	.227	.116	.034	.222	.114	.033	.214	.111	.033	.206	.108	.032	.198	.106	.032	
6.0	.211	.106	.030	.207	.104	.030	.199	.102	.030	.192	.100	.029	.185	.097	.029	
7.0	.197	.097	.028	.193	.096	.027	.186	.094	.027	.179	.092	.027	.173	.090	.026	
8.0	.184	.090	.025	.180	.089	.025	.174	.087	.025	.168	.085	.025	.163	.083	.024	
9.0	.172	.083	.023	.169	.083	.023	.164	.081	.023	.158	.079	.023	.153	.078	.022	
10.0	.162	.078	.022	.159	.077	.021	.154	.076	.021	.149	.074	.021	.145	.073	.021	

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Ceiling Cavity Exitance Coefficients(CCEC)															
0.0	.202	.202	.202	.173	.173	.173	.118	.118	.118	.068	.068	.068	.022	.022	.022	
1.0	.191	.168	.147	.164	.144	.126	.112	.099	.087	.064	.057	.051	.021	.018	.016	
2.0	.183	.144	.110	.157	.124	.095	.107	.085	.067	.062	.050	.039	.020	.016	.013	
3.0	.175	.126	.087	.150	.109	.075	.103	.075	.053	.060	.044	.031	.019	.014	.010	
4.0	.168	.113	.071	.144	.097	.061	.099	.068	.043	.057	.040	.026	.018	.013	.008	
5.0	.160	.102	.059	.138	.088	.052	.095	.062	.036	.055	.036	.022	.018	.012	.007	
6.0	.153	.094	.051	.132	.081	.045	.091	.057	.032	.053	.033	.019	.017	.011	.006	
7.0	.146	.087	.045	.126	.075	.040	.087	.053	.028	.051	.031	.017	.016	.010	.006	
8.0	.140	.081	.041	.121	.070	.036	.083	.049	.025	.049	.029	.015	.016	.010	.005	
9.0	.134	.076	.037	.115	.066	.033	.080	.047	.023	.047	.027	.014	.015	.009	.005	
10.0	.128	.072	.034	.111	.063	.030	.077	.044	.021	.045	.026	.013	.015	.009	.004	

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2021-11-01

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm												
NAME: LLS-BS3360FD1200					TYPE:			WEIGHT:				
SPEC.:LLS-BS3360FD1200					DIM.: 1200*33*60mm			SERIAL No.:				
MFR.: COLORS					SUR.:1200*33mm			Shielding Angle:				
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3		
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3		
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2		
Room dimensions		Viewed crosswise				Viewed endwise						
x = 2H y = 2H	19.4	20.9	19.7	21.1	21.3	19.8	21.3	20.1	21.5	21.8		
	3H	20.6	22.0	20.9	22.2	22.5	21.3	22.6	21.6	22.9	23.2	
	4H	21.0	22.3	21.3	22.6	22.8	21.8	23.1	22.1	23.4	23.7	
	6H	21.1	22.4	21.5	22.7	23.0	22.2	23.4	22.5	23.7	24.0	
	8H	21.2	22.3	21.5	22.6	23.0	22.3	23.4	22.6	23.7	24.1	
	12H	21.1	22.3	21.5	22.6	22.9	22.3	23.4	22.7	23.8	24.1	
	4H	2H	20.0	21.3	20.3	21.6	21.8	20.3	21.6	20.7	21.9	22.2
		3H	21.4	22.5	21.7	22.8	23.1	21.9	23.1	22.3	23.4	23.7
		4H	21.8	22.9	22.2	23.2	23.6	22.6	23.6	23.0	24.0	24.3
		6H	22.1	23.0	22.5	23.4	23.8	23.0	24.0	23.5	24.3	24.7
		8H	22.1	23.0	22.6	23.4	23.8	23.2	24.0	23.6	24.4	24.8
		12H	22.1	22.9	22.6	23.3	23.8	23.3	24.0	23.7	24.5	24.9
8H	4H	22.1	22.9	22.5	23.3	23.7	22.7	23.6	23.2	24.0	24.4	
	6H	22.4	23.1	22.9	23.6	24.0	23.3	24.0	23.8	24.4	24.9	
	8H	22.5	23.1	23.0	23.6	24.1	23.5	24.1	24.0	24.6	25.1	
	12H	22.5	23.1	23.0	23.5	24.0	23.6	24.2	24.1	24.6	25.2	
12H	4H	22.1	22.9	22.5	23.3	23.7	22.7	23.5	23.2	23.9	24.3	
	6H	22.5	23.1	23.0	23.5	24.0	23.3	23.9	23.8	24.4	24.9	
	8H	22.6	23.1	23.1	23.6	24.1	23.5	24.1	24.0	24.5	25.1	
Variations with the observer position at spacings:												
S = 1.0H	+ 0.2 / - 0.3				+ 0.2 / - 0.2							
1.5H	+ 0.2 / - 0.4				+ 0.2 / - 0.3							
2.0H	+ 0.3 / - 0.4				+ 0.3 / - 0.3							

CIE Pub.117, 1937 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = 2.3$)

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2021-11-01

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	58	46	39	57	46	39	56	45	39	33
0.80	68	56	49	67	56	49	65	55	48	41
1.00	76	65	58	75	65	58	73	66	57	50
1.25	83	73	66	82	72	65	79	71	65	57
1.50	88	79	72	87	78	71	83	76	70	62
2.00	95	87	80	93	85	79	89	83	78	70
2.50	99	91	85	97	90	84	93	87	82	74
3.00	102	95	90	100	94	89	96	91	86	78
4.00	106	101	96	104	99	95	99	95	92	82
5.00	109	104	100	106	102	98	101	98	95	85
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2021-11-01

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2021-11-01

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

AAI Figure

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2021-11-01

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:



C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2021-11-01

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

LED Avg.L Report

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	13394
L_0~180(75)av	10879
L_0~180(85)av	6487
L_90~270(65)av	14117
L_90~270(75)av	11877
L_90~270(85)av	7835
L_45(65)av	13775
L_45(75)av	11383
L_45(85)av	6858

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2021-11-01

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JYH
Test Date: 2021-11-01

Range: 0 - 180DEG
Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity: 65.0%
Test Distance: 10.950m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:220.9V I:0.0927A P:19.43W PF:0.9486 Freq:49.99Hz Lamp Flux:1936.78x1 lm		
NAME: LLS-BS3360FD1200	TYPE:	WEIGHT:
SPEC.:LLS-BS3360FD1200	DIM.: 1200*33*60mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*33mm	Shielding Angle:

Table--1

UNIT: cd

C(DEG) g (DEG)	0	45	90	135	180	225	270	315										
0	704	703	702	701	704	703	702	701										
5	696	698	698	699	704	702	698	696										
10	681	685	686	690	696	693	688	683										
15	660	666	669	674	681	677	670	664										
20	631	639	645	651	659	653	647	638										
25	597	607	614	621	630	624	618	606										
30	559	570	580	587	596	590	583	570										
35	516	528	540	548	556	550	544	529										
40	470	483	496	505	513	507	501	484										
45	420	435	450	458	466	459	454	435										
50	368	381	399	407	417	410	402	384										
55	314	328	347	353	361	357	348	330										
60	257	272	292	299	306	302	294	275										
65	199	216	236	243	250	245	237	218										
70	141	158	177	186	193	186	180	160										
75	87.0	104	121	129	136	129	123	105										
80	40.2	54.4	68.6	76.2	82.8	75.9	70.5	55.6										
85	8.00	16.1	26.4	31.1	36.8	30.8	27.7	16.7										
90	4.07	4.05	2.19	4.63	6.57	3.51	0.83	2.41										
95	3.67	3.27	2.04	2.48	2.30	1.47	0.70	2.09										
100	3.53	2.96	2.02	2.10	2.12	1.44	1.16	2.12										
105	3.59	2.97	2.39	2.16	2.16	1.65	1.93	2.16										
110	3.89	3.38	3.10	2.66	2.34	2.16	2.77	2.67										
115	4.29	4.18	3.92	3.26	2.82	2.73	3.54	3.38										
120	5.08	4.91	4.67	3.86	3.46	3.26	4.24	4.06										
125	5.80	5.58	5.30	4.40	4.11	3.82	4.87	4.79										
130	6.48	6.01	5.79	4.94	4.75	4.46	5.46	5.40										
135	7.11	6.41	6.25	5.46	5.41	5.03	5.99	5.88										
140	7.67	6.79	6.69	5.97	6.01	5.59	6.47	6.30										
145	8.19	7.09	7.13	6.49	6.48	6.15	6.81	6.59										
150	8.61	7.34	7.82	7.03	6.97	6.78	7.34	6.90										
155	9.06	7.62	8.54	7.65	7.45	7.46	8.03	7.22										
160	9.54	8.08	9.30	8.32	7.96	8.19	8.89	7.86										
165	9.97	8.87	9.98	9.08	8.53	8.90	9.59	8.66										
170	10.4	9.77	10.5	9.91	8.65	9.63	10.2	9.70										
175	10.0	10.7	11.0	10.8	8.38	10.4	10.9	10.9										
180	9.59	11.3	11.4	11.6	9.60	11.3	11.4	11.6										

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2021-11-01

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks: