


LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm		
NAME: LLS-M60FDXBX1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 101.79 lm/W			
MODEL	LLS-M60FDXBX1200	I _{max} (cd)	1701	S/MH(C0/180)	1.12
NOMINAL POWER(W)	34	LOR(%)	100.0	S/MH(C90/270)	1.08
RATED VOLTAGE(V)	220	TOTAL FLUX(lm)	3814.5	h UP,DN(C0-180)	0.6,52.9
NOMINAL FLUX(lm)	3814.53	CIE CLASS	DIRECT	h UP,DN(C180-360)	0.6,45.9
LAMPS INSIDE	1	h up(%)	1.2	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	220	h down(%)	98.8	CIBSE SHR MAX	1.25



C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2020-09-15

Range: 0 - 180DEG
 Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


g	C0	C45	C90	C135	C180	C225	C270	C315	g	F zone	F total	%lum,lamp
10	1655	1670	1670	1667	1624	1614	1612	1604	0- 10	159.1	159.1	4.17,4.17
20	1497	1539	1541	1541	1442	1437	1435	1427	10- 20	442.2	601.3	15.8,15.8
30	1259	1325	1328	1331	1192	1197	1196	1187	20- 30	631.5	1233	32.3,32.3
40	991.4	1065	1069	1074	925.7	934.8	934.4	926.4	30- 40	701.4	1934	50.7,50.7
50	733.7	799.2	804.1	809.5	674.6	680.0	680.6	673.4	40- 50	662.9	2597	68.1,68.1
60	499.5	551.4	555.2	561.7	448.8	448.5	448.9	442.6	50- 60	546.3	3143	82.4,82.4
70	289.9	325.0	330.9	334.3	244.4	241.5	239.3	237.0	60- 70	380.8	3524	92.4,92.4
80	109.7	133.5	136.8	141.5	78.28	72.13	71.03	69.59	70- 80	197.0	3721	97.6,97.6
90	3.758	10.45	11.86	14.51	0.6753	1.238	1.209	1.840	80- 90	46.81	3768	98.8,98.8
100	2.276	2.425	2.517	3.426	1.955	2.343	2.248	2.603	90-100	2.681	3771	98.9,98.9
110	4.300	3.979	3.920	4.089	3.796	3.977	3.906	4.044	100-110	3.365	3774	98.9,98.9
120	6.682	6.240	6.184	6.178	5.667	5.706	5.658	5.664	110-120	4.919	3779	99.1,99.1
130	9.157	8.805	8.677	8.657	7.655	8.005	7.964	7.977	120-130	6.415	3786	99.2,99.2
140	11.90	10.72	10.58	10.58	10.04	10.70	10.64	10.69	130-140	7.374	3793	99.4,99.4
150	14.67	12.47	12.35	12.32	12.51	14.05	13.98	14.06	140-150	7.497	3800	99.6,99.6
160	17.75	14.56	14.42	14.39	15.67	18.42	18.40	18.53	150-160	6.822	3807	99.8,99.8
170	21.36	18.92	18.86	18.85	19.36	23.20	23.24	23.24	160-170	5.201	3812	99.9,99.9
180	21.66	24.51	24.46	24.41	21.67	24.47	24.47	24.40	170-180	2.104	3815	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2020-09-15

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm		
NAME: LLS-M60FDXBX1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:



LUMINANCE cd/(m2)		
G(180)	C0/180	C90/270
85	8230	11679
80	10530	13129
75	12529	14782
70	14126	16127
65	15432	17355
60	16649	18507
55	17817	19669
50	19023	20850
45	20275	22052


C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm		
NAME: LLS-M60FDXBX1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

rcc	80%			70%			50%			30%			10%			0
r _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.10	1.10	1.10	1.05	1.05	1.05	1.01	1.01	1.01	.99
1.0	1.05	1.01	.97	1.03	.99	.96	.98	.95	.93	.94	.92	.90	.90	.88	.87	.85
2.0	.92	.86	.81	.91	.85	.80	.87	.82	.78	.83	.79	.76	.80	.77	.74	.72
3.0	.82	.74	.68	.80	.73	.68	.77	.71	.66	.74	.69	.65	.72	.67	.64	.62
4.0	.73	.65	.59	.72	.64	.58	.69	.62	.57	.67	.61	.56	.65	.60	.55	.53
5.0	.66	.57	.51	.65	.57	.51	.62	.55	.50	.60	.54	.49	.58	.53	.49	.47
6.0	.60	.51	.45	.59	.51	.45	.57	.50	.44	.55	.49	.44	.53	.48	.43	.41
7.0	.54	.46	.40	.53	.46	.40	.52	.45	.40	.50	.44	.39	.49	.43	.39	.37
8.0	.50	.42	.36	.49	.41	.36	.48	.41	.36	.46	.40	.35	.45	.39	.35	.33
9.0	.46	.38	.33	.45	.38	.33	.44	.37	.32	.43	.37	.32	.42	.36	.32	.30
10.0	.42	.35	.30	.42	.35	.30	.41	.34	.29	.40	.34	.29	.39	.33	.29	.27



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm		
NAME: LLS-M60FDXBX1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Wall Exitance Coefficients(WEC)															
0.0																
1.0	.283	.161	.051	.276	.157	.050	.262	.150	.048	.249	.144	.046	.238	.138	.044	
2.0	.269	.148	.045	.263	.145	.045	.251	.139	.043	.240	.134	.042	.229	.130	.041	
3.0	.251	.134	.040	.246	.132	.040	.235	.127	.039	.225	.123	.038	.216	.120	.037	
4.0	.234	.121	.036	.229	.120	.035	.219	.116	.035	.210	.113	.034	.202	.110	.033	
5.0	.217	.111	.032	.213	.109	.032	.204	.106	.031	.196	.104	.031	.189	.101	.030	
6.0	.203	.102	.029	.199	.100	.029	.191	.098	.028	.184	.096	.028	.177	.093	.028	
7.0	.189	.094	.027	.186	.093	.026	.179	.090	.026	.173	.088	.026	.167	.087	.025	
8.0	.177	.087	.024	.174	.086	.024	.168	.084	.024	.162	.082	.024	.157	.081	.023	
9.0	.167	.081	.023	.164	.080	.022	.158	.078	.022	.153	.077	.022	.148	.075	.022	
10.0	.157	.075	.021	.155	.075	.021	.150	.073	.021	.145	.072	.020	.141	.071	.020	

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Ceiling Cavity Exitance Coefficients(CCEC)															
0.0	.200	.200	.200	.171	.171	.171	.117	.117	.117	.067	.067	.067	.021	.021	.021	
1.0	.188	.166	.146	.161	.142	.125	.110	.098	.087	.063	.057	.050	.020	.018	.016	
2.0	.179	.141	.110	.153	.122	.095	.105	.084	.066	.060	.049	.039	.019	.016	.013	
3.0	.170	.124	.086	.146	.107	.075	.100	.074	.053	.058	.043	.031	.019	.014	.010	
4.0	.163	.110	.070	.139	.095	.061	.096	.066	.043	.055	.039	.025	.018	.013	.008	
5.0	.155	.100	.059	.133	.086	.051	.092	.060	.036	.053	.035	.021	.017	.012	.007	
6.0	.148	.091	.050	.127	.079	.044	.088	.055	.031	.051	.032	.018	.016	.011	.006	
7.0	.141	.084	.044	.122	.073	.038	.084	.051	.027	.049	.030	.016	.016	.010	.005	
8.0	.135	.078	.039	.116	.068	.034	.080	.048	.024	.047	.028	.015	.015	.009	.005	
9.0	.129	.073	.036	.111	.064	.031	.077	.045	.022	.045	.026	.013	.015	.009	.004	
10.0	.124	.069	.033	.107	.060	.029	.074	.042	.020	.043	.025	.012	.014	.008	.004	

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm											
NAME: LLS-M60FDXBX1200						TYPE:		WEIGHT:			
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC						DIM.: 1200*50*45mm		SERIAL No.:			
MFR.: COLORS						SUR.:1200*50mm		Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H	18.1	19.6	18.4	19.8	20.0	18.5	19.9	18.8	20.2	20.4	
	3H	19.4	20.7	19.7	20.9	21.2	19.8	21.1	20.2	21.4	21.7
	4H	19.8	21.1	20.1	21.3	21.6	20.4	21.6	20.7	21.9	22.2
	6H	20.1	21.3	20.5	21.6	21.9	20.7	21.9	21.1	22.2	22.5
	8H	20.2	21.3	20.5	21.6	21.9	20.9	22.0	21.2	22.3	22.6
	12H	20.2	21.3	20.6	21.6	21.9	20.9	22.0	21.3	22.3	22.6
4H	2H	18.7	20.0	19.1	20.2	20.5	19.0	20.3	19.4	20.5	20.8
	3H	20.2	21.2	20.5	21.5	21.9	20.5	21.6	20.9	21.9	22.3
	4H	20.7	21.7	21.1	22.1	22.4	21.2	22.2	21.6	22.5	22.9
	6H	21.1	22.0	21.6	22.4	22.8	21.7	22.6	22.1	22.9	23.3
	8H	21.3	22.1	21.7	22.5	22.9	21.9	22.7	22.3	23.1	23.5
	12H	21.3	22.1	21.8	22.5	22.9	22.0	22.7	22.4	23.1	23.6
8H	4H	21.0	21.8	21.4	22.2	22.6	21.4	22.2	21.8	22.6	23.0
	6H	21.5	22.2	22.0	22.6	23.1	22.0	22.7	22.5	23.1	23.6
	8H	21.7	22.3	22.2	22.8	23.3	22.3	22.9	22.8	23.3	23.8
	12H	21.9	22.4	22.4	22.8	23.3	22.5	23.0	23.0	23.5	24.0
12H	4H	21.0	21.7	21.4	22.2	22.6	21.4	22.1	21.8	22.6	23.0
	6H	21.6	22.2	22.1	22.6	23.1	22.1	22.7	22.6	23.1	23.6
	8H	21.8	22.3	22.3	22.8	23.3	22.4	22.9	22.9	23.3	23.8
Variations with the observer position at spacings:											
S = 1.0H	+ 0.2 / - 0.3					+ 0.2 / - 0.2					
1.5H	+ 0.2 / - 0.3					+ 0.1 / - 0.3					
2.0H	+ 0.2 / - 0.4					+ 0.3 / - 0.3					

CIE Pub.117, 3815 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = 4.7$)

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm		
NAME: LLS-M60FDXBX1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	61	50	44	60	50	43	59	49	43	37
0.80	71	60	53	70	60	53	68	59	53	46
1.00	79	69	62	78	68	62	76	69	61	54
1.25	86	76	70	84	75	69	82	74	68	61
1.50	91	82	75	89	81	75	86	79	73	66
2.00	97	89	83	95	88	82	92	86	81	73
2.50	100	93	88	98	92	87	95	89	85	77
3.00	104	97	92	101	96	91	97	93	89	80
4.00	107	102	98	105	100	96	100	97	93	85
5.00	109	105	101	107	103	100	102	99	96	87
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm		
NAME: LLS-M60FDXBX1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

AAI Figure

Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm		
NAME: LLS-M60FDXBX1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

Flux out:2276 lm




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm		
NAME: LLS-M60FDXB1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JYH
Test Date: 2020-09-15

Range: 0 - 180DEG
Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity: 65.0%
Test Distance: 10.950m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:220.8V I:0.1750A P:37.47W PF:0.9699 Freq:49.99Hz Lamp Flux:3814.53x1 lm		
NAME: LLS-M60FDXBX1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FDXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

Table--1

UNIT: cd

C(DEG) g (DEG)	0	45	90	135	180	225	270	315										
0	1700	1696	1694	1689	1700	1696	1694	1689										
5	1693	1696	1696	1691	1677	1668	1666	1659										
10	1655	1670	1670	1667	1624	1614	1612	1604										
15	1589	1617	1617	1616	1545	1536	1534	1525										
20	1497	1539	1541	1541	1442	1437	1435	1427										
25	1385	1440	1443	1445	1322	1322	1322	1312										
30	1259	1325	1328	1331	1192	1197	1196	1187										
35	1126	1198	1202	1206	1059	1067	1066	1057										
40	991	1065	1069	1074	926	935	934	926										
45	860	931	936	940	797	805	805	797										
50	734	799	804	809	675	680	681	673										
55	613	672	677	682	559	562	562	555										
60	499	551	555	562	449	448	449	443										
65	391	437	440	447	342	341	339	336										
70	290	325	331	334	244	242	239	237										
75	195	224	230	233	155	149	148	145										
80	110	134	137	141	78.3	72.1	71.0	69.6										
85	43.0	58.5	61.1	65.0	22.4	17.8	17.2	16.7										
90	3.76	10.4	11.9	14.5	0.68	1.24	1.21	1.84										
95	1.65	2.23	2.43	3.93	1.16	1.57	1.55	1.93										
100	2.28	2.43	2.52	3.43	1.96	2.34	2.25	2.60										
105	3.19	3.07	3.04	3.53	2.90	3.17	3.08	3.34										
110	4.30	3.98	3.92	4.09	3.80	3.98	3.91	4.04										
115	5.50	5.08	5.00	5.05	4.72	4.76	4.72	4.78										
120	6.68	6.24	6.18	6.18	5.67	5.71	5.66	5.66										
125	7.88	7.55	7.47	7.47	6.63	6.79	6.76	6.79										
130	9.16	8.80	8.68	8.66	7.66	8.01	7.96	7.98										
135	10.5	9.89	9.74	9.72	8.81	9.32	9.27	9.27										
140	11.9	10.7	10.6	10.6	10.0	10.7	10.6	10.7										
145	13.2	11.7	11.5	11.5	11.3	12.2	12.2	12.3										
150	14.7	12.5	12.3	12.3	12.5	14.0	14.0	14.1										
155	16.2	13.4	13.2	13.3	14.0	16.1	16.1	16.2										
160	17.7	14.6	14.4	14.4	15.7	18.4	18.4	18.5										
165	19.4	16.3	16.2	16.2	17.5	20.9	20.9	21.0										
170	21.4	18.9	18.9	18.9	19.4	23.2	23.2	23.2										
175	22.2	22.2	22.0	22.0	20.1	24.0	24.1	23.9										
180	21.7	24.5	24.5	24.4	21.7	24.5	24.5	24.4										

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks: