


## LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm		
NAME: LLS-M60FPXBS1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 88.58 lm/W			
MODEL	LLS-M60FPXBS1200	I <sub>max</sub> (cd)	1439	S/MH(C0/180)	1.24
NOMINAL POWER(W)	34	LOR(%)	100.0	S/MH(C90/270)	1.22
RATED VOLTAGE(V)	220	TOTAL FLUX(lm)	3313.4	h UP,DN(C0-180)	0.6,50.6
NOMINAL FLUX(lm)	3313.41	CIE CLASS	DIRECT	h UP,DN(C180-360)	0.6,48.1
LAMPS INSIDE	1	h up(%)	1.3	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	220	h down(%)	98.7	CIBSE SHR MAX	1.35



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-09-15

Range: 0 - 180DEG  
Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

## ZONAL FLUX DIAGRAM

### ZONAL FLUX DIAGRAM:


g	C0	C45	C90	C135	C180	C225	C270	C315	g	F zone	F total	%lum,lamp
10	1418	1419	1405	1394	1394	1387	1400	1415	0- 10	135.5	135.5	4.09,4.09
20	1336	1343	1319	1294	1289	1282	1311	1335	10- 20	385.2	520.6	15.7,15.7
30	1199	1211	1180	1141	1136	1125	1169	1198	20- 30	574.6	1095	33.1,33.1
40	1014	1025	994.8	927.4	906.4	911.5	984.9	1009	30- 40	674.1	1769	53.4,53.4
50	689.4	734.1	679.1	614.6	565.6	600.8	682.5	718.1	40- 50	633.6	2403	72.5,72.5
60	406.9	450.4	368.4	351.6	315.9	325.2	353.5	428.2	50- 60	457.0	2860	86.3,86.3
70	196.4	199.5	198.1	144.1	136.8	127.9	175.9	180.2	60- 70	260.2	3120	94.2,94.2
80	66.85	86.93	78.43	60.11	42.92	50.99	67.04	71.28	70- 80	117.6	3238	97.7,97.7
90	5.808	14.45	2.221	2.035	1.879	2.471	1.536	9.313	80- 90	33.98	3272	98.7,98.7
100	1.673	2.356	1.817	1.978	2.352	2.258	2.131	1.693	90-100	2.329	3274	98.8,98.8
110	3.153	2.809	2.968	3.077	3.597	2.950	3.395	2.804	100-110	2.621	3277	98.9,98.9
120	5.449	5.143	5.397	5.198	5.302	4.754	5.536	4.513	110-120	4.030	3281	99,99
130	8.373	7.808	8.568	7.711	7.624	7.191	8.564	6.394	120-130	5.736	3286	99.2,99.2
140	11.74	10.07	11.27	10.32	10.15	9.911	11.32	8.838	130-140	7.077	3293	99.4,99.4
150	13.82	11.46	13.23	12.93	11.88	12.88	13.21	10.69	140-150	7.178	3301	99.6,99.6
160	15.85	13.14	16.05	15.88	14.12	16.24	16.18	12.92	150-160	6.319	3307	99.8,99.8
170	18.44	16.82	18.42	19.57	16.79	19.75	18.52	17.00	160-170	4.649	3312	99.9,99.9
180	18.26	20.73	20.32	20.95	18.26	20.83	20.39	20.96	170-180	1.808	3313	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
 C Interval: 45.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:JYH  
 Test Date:2020-09-15

g Range: 0 - 180DEG  
 g Interval: 1.0DEG  
 Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
 Humidity:65.0%  
 Test Distance:10.950m [K=1.0000]  
 Remarks:

### LUMINANCE LIMITATION CURVES

Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm		
NAME: LLS-M60FPXBS1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:



LUMINANCE cd/(m2)		
G(DEG)	C0/180	C90/270
85	6097	5898
80	6417	7527
75	7513	8937
70	9573	9655
65	11387	10887
60	13562	12282
55	15480	14887
50	17875	17608
45	20282	20222


C Range: 0 - 360DEG  
 C Interval: 45.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:JYH  
 Test Date:2020-09-15

g Range: 0 - 180DEG  
 g Interval: 1.0DEG  
 Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
 Humidity:65.0%  
 Test Distance:10.950m [K=1.0000]  
 Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm		
NAME: LLS-M60FPXBS1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

r <sub>cc</sub>	80%			70%			50%			30%			10%			0
r <sub>w</sub>	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r <sub>fc</sub>	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio                      Coefficients of Utilization(CU)															
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.10	1.10	1.10	1.05	1.05	1.05	1.01	1.01	1.01	.99
1.0	1.06	1.02	.99	1.03	1.00	.97	.99	.96	.94	.95	.93	.91	.91	.89	.88	.86
2.0	.94	.88	.83	.92	.86	.82	.88	.84	.80	.85	.81	.78	.82	.78	.76	.74
3.0	.84	.76	.70	.82	.75	.70	.79	.73	.68	.76	.71	.67	.73	.69	.66	.64
4.0	.75	.67	.61	.73	.66	.60	.71	.64	.59	.68	.63	.58	.66	.61	.57	.55
5.0	.67	.59	.53	.66	.58	.53	.64	.57	.52	.62	.56	.51	.60	.55	.51	.49
6.0	.61	.53	.47	.60	.52	.46	.58	.51	.46	.56	.50	.45	.55	.49	.45	.43
7.0	.56	.47	.42	.55	.47	.41	.53	.46	.41	.52	.45	.41	.50	.45	.40	.38
8.0	.51	.43	.37	.50	.43	.37	.49	.42	.37	.48	.41	.37	.46	.41	.36	.35
9.0	.47	.39	.34	.46	.39	.34	.45	.38	.33	.44	.38	.33	.43	.37	.33	.31
10.0	.43	.36	.31	.43	.36	.31	.42	.35	.31	.41	.35	.30	.40	.34	.30	.28



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-09-15

g Range: 0 - 180DEG  
Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

WEC AND CCEC

Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm		
NAME: LLS-M60FPXBS1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Wall Exitance Coefficients(WEC)															
0.0																
1.0	.268	.152	.048	.261	.149	.047	.247	.142	.045	.234	.135	.043	.223	.129	.042	
2.0	.257	.141	.043	.250	.138	.042	.238	.133	.041	.227	.127	.040	.217	.123	.039	
3.0	.241	.129	.038	.236	.126	.038	.225	.122	.037	.215	.118	.036	.206	.114	.035	
4.0	.226	.117	.035	.221	.116	.034	.212	.112	.034	.203	.109	.033	.195	.106	.032	
5.0	.211	.108	.031	.207	.106	.031	.199	.103	.030	.191	.101	.030	.183	.098	.029	
6.0	.198	.099	.028	.194	.098	.028	.186	.096	.028	.179	.093	.027	.173	.091	.027	
7.0	.186	.092	.026	.182	.091	.026	.175	.089	.026	.169	.087	.025	.163	.085	.025	
8.0	.175	.085	.024	.171	.084	.024	.165	.083	.024	.160	.081	.023	.154	.079	.023	
9.0	.165	.080	.022	.162	.079	.022	.156	.077	.022	.151	.076	.022	.146	.074	.021	
10.0	.156	.075	.021	.153	.074	.021	.148	.073	.020	.143	.071	.020	.139	.070	.020	

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Ceiling Cavity Exitance Coefficients(CCEC)															
0.0	.200	.200	.200	.171	.171	.171	.117	.117	.117	.067	.067	.067	.021	.021	.021	
1.0	.187	.166	.147	.160	.143	.127	.109	.098	.088	.063	.057	.051	.020	.018	.016	
2.0	.177	.142	.112	.152	.122	.097	.104	.084	.068	.060	.049	.040	.019	.016	.013	
3.0	.169	.124	.088	.145	.107	.076	.099	.074	.054	.057	.043	.032	.018	.014	.010	
4.0	.161	.110	.072	.138	.095	.062	.095	.066	.044	.055	.039	.026	.018	.013	.009	
5.0	.154	.100	.060	.132	.086	.052	.091	.060	.037	.053	.035	.022	.017	.012	.007	
6.0	.147	.091	.051	.126	.079	.045	.087	.055	.032	.051	.033	.019	.016	.011	.006	
7.0	.140	.084	.045	.121	.073	.039	.083	.051	.028	.048	.030	.017	.016	.010	.005	
8.0	.134	.078	.040	.116	.068	.035	.080	.048	.025	.047	.028	.015	.015	.009	.005	
9.0	.129	.074	.036	.111	.064	.032	.077	.045	.022	.045	.026	.013	.014	.009	.004	
10.0	.123	.069	.033	.106	.060	.029	.074	.042	.021	.043	.025	.012	.014	.008	.004	

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-09-15

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

UGR(Unified Glare Rating) Table

Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm											
NAME: LLS-M60FPXBS1200					TYPE:			WEIGHT:			
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC					DIM.: 1200*50*45mm			SERIAL No.:			
MFR.: COLORS					SUR.:1200*50mm			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise				Viewed endwise					
x = 2H y = 2H	18.2	19.6	18.5	19.8	20.0	18.0	19.4	18.3	19.6	19.8	
	3H	18.9	20.2	19.3	20.5	20.7	18.8	20.1	19.1	20.3	20.6
	4H	19.2	20.4	19.5	20.6	20.9	19.1	20.3	19.4	20.6	20.8
	6H	19.3	20.4	19.6	20.7	21.0	19.3	20.5	19.7	20.7	21.0
	8H	19.3	20.4	19.7	20.7	21.0	19.4	20.5	19.7	20.8	21.1
	12H	19.4	20.4	19.7	20.7	21.0	19.4	20.4	19.8	20.8	21.1
4H	2H	18.6	19.8	18.9	20.0	20.3	18.4	19.6	18.8	19.9	20.2
	3H	19.5	20.5	19.8	20.8	21.1	19.4	20.4	19.7	20.7	21.0
	4H	19.8	20.7	20.2	21.1	21.4	19.8	20.7	20.1	21.0	21.4
	6H	20.0	20.8	20.4	21.2	21.6	20.1	20.9	20.5	21.3	21.7
	8H	20.1	20.9	20.5	21.2	21.7	20.2	21.0	20.6	21.4	21.8
	12H	20.2	20.9	20.6	21.3	21.7	20.3	21.0	20.7	21.4	21.8
8H	4H	19.9	20.6	20.3	21.0	21.4	19.9	20.6	20.3	21.0	21.4
	6H	20.2	20.9	20.7	21.3	21.7	20.3	21.0	20.8	21.4	21.9
	8H	20.4	21.0	20.9	21.4	21.9	20.5	21.1	21.0	21.5	22.0
	12H	20.5	21.0	21.0	21.5	22.0	20.7	21.1	21.1	21.6	22.1
12H	4H	19.9	20.6	20.3	21.0	21.4	19.9	20.6	20.3	21.0	21.4
	6H	20.3	20.8	20.8	21.3	21.8	20.4	20.9	20.9	21.4	21.9
	8H	20.5	21.0	21.0	21.4	21.9	20.6	21.1	21.1	21.5	22.0
Variations with the observer position at spacings:											
S = 1.0H	+ 0.4 / - 0.5				+ 0.4 / - 0.4						
1.5H	+ 0.2 / - 0.4				+ 0.2 / - 0.4						
2.0H	+ 0.6 / - 0.7				+ 0.6 / - 0.9						

CIE Pub.117, 3313 lm Total Lamp Luminous Flux Correct ( $8\log(F/F_0) = 4.2$ )

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-09-15

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

UTILIZATION FACTORS TABLE

Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm		
NAME: LLS-M60FPXBS1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	62	52	45	62	51	45	60	51	45	39
0.80	73	62	55	71	62	55	70	61	55	48
1.00	81	71	64	80	70	64	77	71	64	57
1.25	88	78	72	86	78	72	84	76	71	64
1.50	92	84	78	91	83	77	88	81	76	69
2.00	98	91	85	97	90	85	93	87	83	76
2.50	102	95	90	100	93	89	96	91	87	79
3.00	105	99	94	102	97	93	98	94	90	82
4.00	108	103	99	106	101	97	101	98	95	86
5.00	110	106	102	107	104	101	103	100	97	88
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG  
 C Interval: 45.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:JYH  
 Test Date:2020-09-15

g Range: 0 - 180DEG  
 g Interval: 1.0DEG  
 Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
 Humidity:65.0%  
 Test Distance:10.950m [K=1.0000]  
 Remarks:

### ISOCANDELA DIAGRAM

Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm		
NAME: LLS-M60FPXBS1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-09-15


deg Range: 0 - 180DEG  
Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:



### AAI Figure

Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm		
NAME: LLS-M60FPXBS1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

Flux out:2288 lm




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-09-15

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

### ISOLUX DIAGRAM


Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm		
NAME: LLS-M60FPXBS1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:



C Range: 0 - 360DEG  
 C Interval: 45.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:JYH  
 Test Date:2020-09-15

Range: 0 - 180DEG  
 Interval: 1.0DEG  
 Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
 Humidity:65.0%  
 Test Distance:10.950m [K=1.0000]  
 Remarks:

### Planar Illuminance Curve



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: JYH  
Test Date: 2020-09-15

deg Range: 0 - 180DEG  
deg Interval: 1.0DEG  
Test System: EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity: 65.0%  
Test Distance: 10.950m [K=1.0000]  
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:220.8V I:0.1747A P:37.40W PF:0.9699 Freq:49.99Hz Lamp Flux:3313.41x1 lm		
NAME: LLS-M60FPXBS1200	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS1200-T37NW8B-DC	DIM.: 1200*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:1200*50mm	Shielding Angle:

Table--1

UNIT: cd

C(DEG) g (DEG)	0	45	90	135	180	225	270	315										
0	1438	1433	1432	1435	1438	1433	1432	1435										
5	1436	1434	1426	1422	1424	1418	1424	1433										
10	1418	1419	1405	1394	1394	1387	1400	1415										
15	1385	1388	1369	1351	1349	1342	1362	1382										
20	1336	1343	1319	1294	1289	1282	1311	1335										
25	1274	1284	1256	1224	1217	1210	1246	1273										
30	1199	1211	1180	1141	1136	1125	1169	1198										
35	1116	1126	1094	1044	1043	1027	1082	1111										
40	1014	1025	995	927	906	911	985	1009										
45	860	901	858	768	727	752	858	887										
50	689	734	679	615	566	601	682	718										
55	533	583	512	479	435	458	511	565										
60	407	450	368	352	316	325	353	428										
65	289	315	276	227	221	206	247	291										
70	196	199	198	144	137	128	176	180										
75	117	125	139	90.1	80.3	83.3	120	112										
80	66.9	86.9	78.4	60.1	42.9	51.0	67.0	71.3										
85	31.9	49.1	30.8	24.1	13.6	18.1	27.9	41.3										
90	5.81	14.5	2.22	2.03	1.88	2.47	1.54	9.31										
95	1.32	2.34	1.86	1.82	1.87	2.36	1.31	1.42										
100	1.67	2.36	1.82	1.98	2.35	2.26	2.13	1.69										
105	2.32	2.39	2.17	2.35	2.93	2.44	2.83	2.12										
110	3.15	2.81	2.97	3.08	3.60	2.95	3.40	2.80										
115	4.20	3.80	4.05	4.13	4.36	3.78	4.42	3.64										
120	5.45	5.14	5.40	5.20	5.30	4.75	5.54	4.51										
125	6.76	6.45	6.96	6.40	6.38	5.89	6.99	5.32										
130	8.37	7.81	8.57	7.71	7.62	7.19	8.56	6.39										
135	10.1	8.99	10.1	9.04	9.02	8.52	10.1	7.65										
140	11.7	10.1	11.3	10.3	10.1	9.91	11.3	8.84										
145	12.8	10.7	12.1	11.6	11.0	11.4	12.2	9.82										
150	13.8	11.5	13.2	12.9	11.9	12.9	13.2	10.7										
155	14.8	12.1	14.6	14.3	12.9	14.5	14.7	11.7										
160	15.9	13.1	16.1	15.9	14.1	16.2	16.2	12.9										
165	17.1	14.8	17.3	17.7	15.4	17.9	17.4	14.7										
170	18.4	16.8	18.4	19.6	16.8	19.7	18.5	17.0										
175	18.5	19.2	19.5	20.4	17.2	20.3	19.6	19.5										
180	18.3	20.7	20.3	21.0	18.3	20.8	20.4	21.0										

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-09-15

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks: