


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm		
NAME: LLS-M60FPXBS0600	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC	DIM.: 600*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:600*50mm	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 84.76 lm/W			
MODEL	LLS-M60FPXBS0600	I _{max} (cd)	702.6	S/MH(C0/180)	1.20
NOMINAL POWER(W)	17	LOR(%)	100.0	S/MH(C90/270)	1.21
RATED VOLTAGE(V)	220	TOTAL FLUX(lm)	1624.0	h UP,DN(C0-180)	0.7,49.4
NOMINAL FLUX(lm)	1624.05	CIE CLASS	DIRECT	h UP,DN(C180-360)	0.6,49.3
LAMPS INSIDE	1	h up(%)	1.3	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	220	h down(%)	98.7	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


g	C0	C45	C90	C135	C180	C225	C270	C315	g	F zone	F total	%lum,lamp
10	684.0	692.2	692.1	681.7	690.9	681.0	679.4	684.7	0- 10	66.17	66.17	4.07,4.07
20	636.8	651.5	653.5	638.6	649.7	635.5	634.6	640.9	10- 20	188.2	254.4	15.7,15.7
30	562.4	583.2	586.7	569.7	580.8	564.2	564.7	571.5	20- 30	281.2	535.6	33,33
40	454.5	483.2	495.5	471.9	488.0	466.7	474.8	471.9	30- 40	329.9	865.5	53.3,53.3
50	293.4	328.1	337.2	319.6	326.7	321.6	328.1	324.8	40- 50	310.0	1176	72.4,72.4
60	163.1	195.5	182.7	194.7	195.1	185.0	174.2	189.5	50- 60	224.0	1400	86.2,86.2
70	72.58	82.61	97.44	85.71	95.53	74.98	87.25	79.24	60- 70	128.3	1528	94.1,94.1
80	22.48	34.61	37.88	37.13	33.54	31.49	34.46	30.37	70- 80	58.38	1586	97.7,97.7
90	0.8107	1.118	1.029	2.764	2.724	1.046	0.6522	1.372	80- 90	16.72	1603	98.7,98.7
100	0.8347	0.9219	0.9787	2.044	0.4827	0.9575	0.6968	1.109	90-100	1.047	1604	98.8,98.8
110	1.673	1.452	1.506	2.246	1.130	1.549	1.605	1.609	100-110	1.312	1605	98.8,98.8
120	2.903	2.888	3.149	3.066	2.071	2.531	3.034	2.517	110-120	2.124	1607	99,99
130	4.475	4.510	5.423	3.996	3.348	3.399	4.765	3.639	120-130	3.106	1611	99.2,99.2
140	5.942	6.179	7.058	5.104	4.650	4.445	5.866	4.989	130-140	3.779	1614	99.4,99.4
150	6.799	7.329	7.799	6.120	5.527	5.629	6.172	5.843	140-150	3.750	1618	99.6,99.6
160	7.793	7.889	7.939	7.140	6.655	6.806	6.400	6.212	150-160	3.117	1621	99.8,99.8
170	8.869	8.150	8.035	8.116	8.056	7.868	7.528	6.799	160-170	2.111	1623	100,100
180	8.830	9.077	9.171	8.777	8.850	9.071	9.204	8.757	170-180	0.7875	1624	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2020-09-15

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm		
NAME: LLS-M60FPXBS0600	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC	DIM.: 600*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:600*50mm	Shielding Angle:



LUMINANCE cd/(m2)		
G(DEG)	C0/180	C90/270
85	2866	5518
80	4315	7271
75	5428	8719
70	7074	9496
65	9030	10788
60	10876	12183
55	13020	14804
50	15215	17485
45	17534	20072


C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2020-09-15

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm		
NAME: LLS-M60FPXBS0600	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC	DIM.: 600*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:600*50mm	Shielding Angle:

r _{cc}	80%			70%			50%			30%			10%			0
r _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Coefficients of Utilization(CU)															
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.10	1.10	1.10	1.05	1.05	1.05	1.01	1.01	1.01	.99
1.0	1.06	1.02	.99	1.03	.90	.97	.99	.96	.94	.95	.93	.91	.91	.89	.88	.86
2.0	.94	.88	.83	.92	.86	.82	.88	.83	.79	.85	.81	.77	.82	.78	.76	.73
3.0	.83	.76	.70	.82	.75	.70	.79	.73	.68	.76	.71	.67	.73	.69	.66	.63
4.0	.75	.67	.61	.73	.66	.60	.71	.64	.59	.68	.63	.58	.66	.61	.57	.55
5.0	.67	.59	.53	.66	.58	.53	.64	.57	.52	.62	.56	.51	.60	.55	.51	.49
6.0	.61	.53	.47	.60	.52	.46	.58	.51	.46	.56	.50	.45	.55	.49	.45	.43
7.0	.56	.47	.42	.55	.47	.41	.53	.46	.41	.52	.45	.41	.50	.45	.40	.38
8.0	.51	.43	.37	.50	.43	.37	.49	.42	.37	.47	.41	.37	.46	.41	.36	.34
9.0	.47	.39	.34	.46	.39	.34	.45	.38	.33	.44	.38	.33	.43	.37	.33	.31
10.0	.43	.36	.31	.43	.36	.31	.42	.35	.30	.41	.35	.30	.40	.34	.30	.28



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm		
NAME: LLS-M60FPXBS0600	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC	DIM.: 600*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:600*50mm	Shielding Angle:

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Wall Exitance Coefficients(WEC)															
0.0																
1.0	.268	.153	.048	.261	.149	.047	.247	.142	.045	.235	.135	.043	.223	.129	.042	
2.0	.257	.141	.043	.251	.138	.043	.239	.133	.041	.228	.128	.040	.217	.123	.039	
3.0	.242	.129	.039	.236	.126	.038	.225	.122	.037	.216	.118	.036	.206	.114	.035	
4.0	.226	.118	.035	.221	.116	.034	.212	.112	.034	.203	.109	.033	.195	.106	.032	
5.0	.212	.108	.031	.207	.106	.031	.199	.103	.030	.191	.101	.030	.184	.098	.029	
6.0	.198	.099	.028	.194	.098	.028	.187	.096	.028	.180	.093	.027	.173	.091	.027	
7.0	.186	.092	.026	.182	.091	.026	.176	.089	.026	.169	.087	.025	.163	.085	.025	
8.0	.175	.085	.024	.172	.084	.024	.165	.083	.024	.160	.081	.023	.154	.079	.023	
9.0	.165	.080	.022	.162	.079	.022	.156	.077	.022	.151	.076	.022	.146	.074	.021	
10.0	.156	.075	.021	.153	.074	.021	.148	.073	.020	.143	.071	.020	.139	.070	.020	

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Ceiling Cavity Exitance Coefficients(CCEC)															
0.0	.200	.200	.200	.171	.171	.171	.117	.117	.117	.067	.067	.067	.021	.021	.021	
1.0	.187	.166	.148	.160	.143	.127	.110	.098	.088	.063	.057	.051	.020	.018	.017	
2.0	.178	.142	.112	.152	.122	.097	.104	.085	.068	.060	.049	.040	.019	.016	.013	
3.0	.169	.124	.088	.145	.107	.077	.100	.074	.054	.058	.043	.032	.018	.014	.010	
4.0	.161	.111	.072	.138	.096	.062	.095	.067	.044	.055	.039	.026	.018	.013	.009	
5.0	.154	.100	.060	.132	.087	.052	.091	.060	.037	.053	.035	.022	.017	.012	.007	
6.0	.147	.092	.052	.127	.079	.045	.087	.055	.032	.051	.033	.019	.016	.011	.006	
7.0	.141	.085	.045	.121	.073	.039	.084	.051	.028	.049	.030	.017	.016	.010	.005	
8.0	.135	.079	.040	.116	.068	.035	.080	.048	.025	.047	.028	.015	.015	.009	.005	
9.0	.129	.074	.037	.111	.064	.032	.077	.045	.023	.045	.027	.014	.015	.009	.004	
10.0	.124	.070	.034	.107	.060	.029	.074	.043	.021	.043	.025	.012	.014	.008	.004	

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2020-09-15

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

UGR(Unified Glare Rating) Table

Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm											
NAME: LLS-M60FPXBS0600					TYPE:			WEIGHT:			
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC					DIM.: 600*50*45mm			SERIAL No.:			
MFR.: COLORS					SUR.:600*50mm			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H	19.7	21.1	20.0	21.3	21.5	20.2	21.6	20.5	21.8	22.0	
	3H	20.3	21.6	20.6	21.8	22.1	21.0	22.2	21.3	22.5	22.7
	4H	20.5	21.7	20.8	21.9	22.2	21.3	22.5	21.6	22.7	23.0
	6H	20.5	21.7	20.9	21.9	22.2	21.5	22.6	21.8	22.9	23.2
	8H	20.5	21.6	20.9	21.9	22.2	21.5	22.6	21.9	22.9	23.2
	12H	20.5	21.5	20.9	21.9	22.2	21.6	22.6	21.9	22.9	23.2
4H	2H	20.1	21.3	20.4	21.6	21.8	20.5	21.7	20.8	21.9	22.2
	3H	20.8	21.8	21.2	22.2	22.5	21.4	22.4	21.7	22.7	23.1
	4H	21.0	22.0	21.4	22.3	22.7	21.8	22.7	22.2	23.1	23.4
	6H	21.2	22.0	21.6	22.4	22.8	22.1	23.0	22.6	23.3	23.7
	8H	21.2	22.0	21.7	22.4	22.8	22.2	23.0	22.7	23.4	23.8
	12H	21.2	21.9	21.7	22.4	22.8	22.3	23.0	22.7	23.4	23.8
8H	4H	21.1	21.9	21.6	22.3	22.7	21.9	22.6	22.3	23.0	23.4
	6H	21.4	22.1	21.9	22.5	22.9	22.3	23.0	22.8	23.4	23.8
	8H	21.5	22.1	22.0	22.5	23.0	22.5	23.0	23.0	23.5	24.0
	12H	21.6	22.0	22.1	22.5	23.0	22.6	23.1	23.1	23.5	24.0
12H	4H	21.1	21.9	21.6	22.3	22.7	21.8	22.5	22.3	22.9	23.4
	6H	21.5	22.0	21.9	22.5	22.9	22.3	22.9	22.8	23.3	23.8
	8H	21.6	22.1	22.1	22.5	23.0	22.5	23.0	23.0	23.5	24.0
Variations with the observer position at spacings:											
S = 1.0H	+ 0.5 / - 0.6					+ 0.4 / - 0.4					
1.5H	+ 0.2 / - 0.4					+ 0.2 / - 0.3					
2.0H	+ 0.7 / - 1.0					+ 0.8 / - 0.8					

CIE Pub.117, 1624 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = 1.7$)

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm		
NAME: LLS-M60FPXBS0600	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC	DIM.: 600*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:600*50mm	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	62	52	45	62	51	45	60	51	45	39
0.80	72	62	55	71	61	55	70	61	55	48
1.00	81	71	64	80	70	64	77	71	63	57
1.25	88	78	72	86	78	72	83	76	71	64
1.50	92	84	77	91	83	77	88	81	76	69
2.00	98	91	85	96	90	84	93	87	83	75
2.50	102	95	90	100	93	89	96	91	87	79
3.00	104	99	94	102	97	93	98	94	90	82
4.00	108	103	99	105	101	97	101	98	95	86
5.00	110	106	102	107	104	100	103	100	97	88
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2020-09-15

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm		
NAME: LLS-M60FPXBS0600	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC	DIM.: 600*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:600*50mm	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

deg Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

AAI Figure

Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm		
NAME: LLS-M60FPXBS0600	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC	DIM.: 600*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:600*50mm	Shielding Angle:

Flux out:1120 lm




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JYH
Test Date: 2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity: 65.0%
Test Distance: 10.950m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm		
NAME: LLS-M60FPXBS0600	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC	DIM.: 600*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:600*50mm	Shielding Angle:



C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2020-09-15

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JYH
Test Date: 2020-09-15

Range: 0 - 180DEG
Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity: 65.0%
Test Distance: 10.950m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:220.8V I:0.0901A P:19.16W PF:0.9636 Freq:49.99Hz Lamp Flux:1624.05x1 lm		
NAME: LLS-M60FPXBS0600	TYPE:	WEIGHT:
SPEC.:LLS-M60FPXBS0600-T19NW8B-DC	DIM.: 600*50*45mm	SERIAL No.:
MFR.: COLORS	SUR.:600*50mm	Shielding Angle:

Table--1

UNIT: cd

C(DEG) g (DEG)	0	45	90	135	180	225	270	315										
0	702	702	700	698	702	702	700	698										
5	697	701	700	693	700	695	692	696										
10	684	692	692	682	691	681	679	685										
15	664	675	676	664	674	662	660	665										
20	637	652	653	639	650	636	635	641										
25	602	621	623	607	618	603	603	609										
30	562	583	587	570	581	564	565	572										
35	517	537	544	525	539	519	522	525										
40	455	483	495	472	488	467	475	472										
45	372	412	426	399	410	400	413	405										
50	293	328	337	320	327	322	328	325										
55	224	257	255	253	253	249	247	253										
60	163	195	183	195	195	185	174	189										
65	114	130	137	130	140	120	122	124										
70	72.6	82.6	97.4	85.7	95.5	75.0	87.2	79.2										
75	42.1	51.9	67.7	52.6	57.8	48.4	59.7	48.5										
80	22.5	34.6	37.9	37.1	33.5	31.5	34.5	30.4										
85	7.49	15.5	14.4	19.3	15.7	15.2	14.7	16.0										
90	0.81	1.12	1.03	2.76	2.72	1.05	0.65	1.37										
95	0.67	0.82	0.98	2.13	0.30	0.63	0.72	1.01										
100	0.83	0.92	0.98	2.04	0.48	0.96	0.70	1.11										
105	1.17	1.08	1.04	2.07	0.75	1.18	1.06	1.34										
110	1.67	1.45	1.51	2.25	1.13	1.55	1.60	1.61										
115	2.25	2.11	2.22	2.65	1.55	1.99	2.28	1.94										
120	2.90	2.89	3.15	3.07	2.07	2.53	3.03	2.52										
125	3.69	3.68	4.26	3.51	2.68	2.97	3.93	3.09										
130	4.48	4.51	5.42	4.00	3.35	3.40	4.77	3.64										
135	5.31	5.42	6.43	4.56	4.04	3.90	5.46	4.22										
140	5.94	6.18	7.06	5.10	4.65	4.44	5.87	4.99										
145	6.38	6.82	7.47	5.62	5.07	5.01	6.07	5.52										
150	6.80	7.33	7.80	6.12	5.53	5.63	6.17	5.84										
155	7.23	7.69	7.87	6.63	6.06	6.25	6.27	6.10										
160	7.79	7.89	7.94	7.14	6.66	6.81	6.40	6.21										
165	8.29	8.04	7.96	7.69	7.31	7.37	6.81	6.39										
170	8.87	8.15	8.03	8.12	8.06	7.87	7.53	6.80										
175	8.77	8.53	8.53	8.34	8.44	8.34	8.41	7.72										
180	8.83	9.08	9.17	8.78	8.85	9.07	9.20	8.76										

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-15

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks: