


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm		
NAME: DJ602408NO	TYPE:	WEIGHT:
SPEC.:DJ602408NO-8NWN5A012WC0100	DIM.: 1000*8*1.5mm	SERIAL No.:
MFR.: COLORS	SUR.:1000*8mm	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 119.60 lm/W			
MODEL	DJ602408NO	Imax(cd)	172.1	S/MH(C0/180)	1.31
NOMINAL POWER(W)	4.4	LOR(%)	100.0	S/MH(C90/270)	1.29
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	525.02	h UP,DN(C0-180)	0.8,50.3
NOMINAL FLUX(lm)	525.024	CIE CLASS	DIRECT	h UP,DN(C180-360)	0.7,48.1
LAMPS INSIDE	1	h up(%)	1.6	CIBSE SHR NOM	1.50
TEST VOLTAGE(V)	24	h down(%)	98.4	CIBSE SHR MAX	1.50

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2020-09-04

g Range: 0 - 180DEG
 Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


g	C0	C45	C90	C135	C180	C225	C270	C315	g	F zone	F total	%lum,lamp
10	170.3	170.6	170.1	169.8	169.0	168.9	169.2	169.8	0- 10	16.31	16.31	3.11,3.11
20	163.6	164.0	163.2	162.5	160.9	160.7	161.4	162.4	10- 20	47.07	63.38	12.1,12.1
30	151.7	152.3	151.2	150.1	147.8	147.5	148.6	149.9	20- 30	72.28	135.7	25.8,25.8
40	134.6	135.4	134.0	132.6	129.7	129.3	130.7	132.3	30- 40	88.68	224.3	42.7,42.7
50	112.4	113.3	111.6	110.0	106.7	106.1	107.8	109.6	40- 50	93.78	318.1	60.6,60.6
60	85.25	86.16	84.33	82.68	79.05	78.45	80.16	82.16	50- 60	86.22	404.3	77,77
70	54.02	54.90	52.98	51.38	47.92	47.26	48.92	50.92	60- 70	66.20	470.5	89.6,89.6
80	22.25	22.79	21.25	19.91	17.35	16.81	18.14	19.64	70- 80	36.96	507.5	96.7,96.7
90	1.706	1.837	0.8640	1.202	0.5510	0.4662	0.1536	0.8265	80- 90	9.292	516.8	98.4,98.4
100	0.5277	0.6086	0.5678	0.6353	0.4744	0.4008	0.4485	0.4048	90-100	0.5485	517.3	98.5,98.5
110	0.9266	0.9359	0.8214	0.9492	0.9357	0.8148	0.8885	0.8282	100-110	0.7221	518.1	98.7,98.7
120	1.349	1.364	1.289	1.370	1.330	1.135	1.249	1.247	110-120	1.086	519.1	98.9,98.9
130	1.768	1.690	1.622	1.683	1.710	1.476	1.536	1.522	120-130	1.314	520.5	99.1,99.1
140	2.030	1.918	1.910	1.951	1.991	1.803	1.743	1.696	130-140	1.359	521.8	99.4,99.4
150	2.211	2.044	2.050	2.245	2.158	2.137	1.938	1.803	140-150	1.240	523.1	99.6,99.6
160	2.445	2.178	2.377	2.512	2.378	2.431	2.378	2.004	150-160	1.017	524.1	99.8,99.8
170	2.579	2.585	2.738	2.739	2.391	2.645	2.739	2.531	160-170	0.6989	524.8	100,100
180	2.505	2.966	2.972	3.073	2.525	2.972	3.019	3.066	170-180	0.2581	525.0	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-04

g Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES

Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm		
NAME: DJ602408NO	TYPE:	WEIGHT:
SPEC.:DJ602408NO-8NWNSA012WC0100	DIM.: 1000*8*1.5mm	SERIAL No.:
MFR.: COLORS	SUR.:1000*8mm	Shielding Angle:



LUMINANCE cd/(m2)		
G(°)	C0/180	C90/270
85	13277	12271
80	16013	15299
75	18215	17728
70	19744	19364
65	20709	20427
60	21311	21082
55	21666	21491
50	21851	21705
45	21946	21829


C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-04

g Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm		
NAME: DJ602408NO	TYPE:	WEIGHT:
SPEC.:DJ602408NO-8NWN5A012WC0100	DIM.: 1000*8*1.5mm	SERIAL No.:
MFR.: COLORS	SUR.:1000*8mm	Shielding Angle:

r _{cc}	80%			70%			50%			30%			10%			0
r _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Coefficients of Utilization(CU)															
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.10	1.10	1.10	1.05	1.05	1.05	1.01	1.01	1.01	.98
1.0	1.03	.99	.95	1.01	.97	.93	.96	.93	.90	.92	.90	.87	.88	.86	.84	.82
2.0	.90	.83	.77	.88	.82	.76	.84	.79	.74	.81	.76	.72	.77	.74	.70	.68
3.0	.79	.70	.64	.77	.69	.63	.74	.67	.62	.71	.65	.61	.68	.63	.59	.57
4.0	.70	.61	.54	.68	.60	.53	.65	.58	.52	.63	.57	.52	.60	.55	.51	.48
5.0	.62	.53	.46	.61	.52	.46	.58	.51	.45	.56	.50	.45	.54	.49	.44	.42
6.0	.56	.47	.40	.55	.46	.40	.53	.45	.39	.51	.44	.39	.49	.43	.38	.36
7.0	.50	.42	.35	.50	.41	.35	.48	.40	.35	.46	.39	.34	.45	.39	.34	.32
8.0	.46	.37	.31	.45	.37	.31	.44	.36	.31	.42	.36	.31	.41	.35	.30	.28
9.0	.42	.34	.28	.41	.34	.28	.40	.33	.28	.39	.32	.28	.38	.32	.27	.26
10.0	.39	.31	.26	.38	.31	.25	.37	.30	.25	.36	.30	.25	.35	.29	.25	.23



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-04

g Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm		
NAME: DJ602408NO	TYPE:	WEIGHT:
SPEC.:DJ602408NO-8NWN5A012WC0100	DIM.: 1000*8*1.5mm	SERIAL No.:
MFR.: COLORS	SUR.:1000*8mm	Shielding Angle:

rcc	80%			70%			50%			30%			10%			0														
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0														
rfc	20%			20%			20%			20%			20%			0														
RCR	RCR:Room Cavity Ratio															Wall Exitance Coefficients(WEC)														
0.0																														
1.0	.311	.177	.056	.304	.173	.055	.289	.166	.053	.276	.159	.051	.264	.153	.049															
2.0	.293	.161	.049	.287	.158	.049	.274	.152	.047	.263	.147	.046	.252	.143	.045															
3.0	.272	.145	.043	.266	.142	.043	.255	.138	.042	.244	.134	.041	.235	.130	.040															
4.0	.251	.130	.038	.245	.128	.038	.236	.125	.037	.226	.122	.037	.218	.118	.036															
5.0	.232	.118	.034	.227	.117	.034	.218	.114	.033	.210	.111	.033	.202	.108	.032															
6.0	.215	.108	.031	.211	.106	.031	.203	.104	.030	.195	.102	.030	.188	.099	.029															
7.0	.200	.099	.028	.196	.098	.028	.189	.096	.028	.182	.094	.027	.176	.092	.027															
8.0	.187	.091	.026	.183	.090	.025	.177	.088	.025	.171	.087	.025	.165	.085	.025															
9.0	.175	.085	.024	.172	.084	.023	.166	.082	.023	.161	.081	.023	.156	.079	.023															
10.0	.164	.079	.022	.162	.078	.022	.156	.077	.022	.151	.075	.021	.147	.074	.021															

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Ceiling Cavity Exitance Coefficients(CCEC)												
0.0	.202	.202	.202	.173	.173	.173	.118	.118	.118	.068	.068	.068	.022	.022	.022	
1.0	.192	.168	.146	.165	.144	.126	.113	.099	.087	.065	.057	.051	.021	.018	.016	
2.0	.185	.144	.110	.158	.124	.095	.108	.086	.066	.062	.050	.039	.020	.016	.013	
3.0	.177	.127	.086	.152	.109	.075	.104	.076	.052	.060	.044	.031	.019	.014	.010	
4.0	.169	.113	.070	.145	.098	.061	.100	.068	.043	.058	.040	.025	.019	.013	.008	
5.0	.162	.103	.059	.139	.089	.052	.096	.062	.036	.056	.037	.022	.018	.012	.007	
6.0	.155	.095	.051	.133	.082	.045	.092	.057	.032	.053	.034	.019	.017	.011	.006	
7.0	.148	.088	.045	.127	.076	.040	.088	.053	.028	.051	.031	.017	.017	.010	.006	
8.0	.142	.082	.041	.122	.071	.036	.084	.050	.025	.049	.029	.015	.016	.010	.005	
9.0	.136	.077	.038	.117	.067	.033	.081	.047	.023	.047	.028	.014	.015	.009	.005	
10.0	.130	.073	.035	.112	.063	.030	.078	.044	.022	.045	.026	.013	.015	.009	.004	

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-04

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm											
NAME: DJ602408NO						TYPE:		WEIGHT:			
SPEC.:DJ602408NO-8NWNSA012WC0100						DIM.: 1000*8*1.5mm		SERIAL No.:			
MFR.: COLORS						SUR.:1000*8mm		Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H	25.9	27.5	26.2	27.7	27.9	25.9	27.4	26.2	27.6	27.9	
	3H	27.5	28.9	27.9	29.2	29.5	27.5	28.9	27.8	29.1	29.4
	4H	28.2	29.5	28.5	29.8	30.1	28.1	29.4	28.4	29.7	30.0
	6H	28.6	29.8	28.9	30.1	30.4	28.5	29.7	28.8	30.0	30.3
	8H	28.7	29.9	29.1	30.2	30.5	28.6	29.8	29.0	30.1	30.4
	12H	28.8	29.9	29.1	30.3	30.6	28.6	29.8	29.0	30.1	30.5
4H	2H	26.6	27.9	26.9	28.2	28.5	26.6	27.9	26.9	28.2	28.5
	3H	28.4	29.5	28.7	29.8	30.2	28.3	29.5	28.7	29.8	30.1
	4H	29.1	30.2	29.5	30.5	30.9	29.0	30.1	29.4	30.4	30.8
	6H	29.6	30.6	30.1	31.0	31.4	29.6	30.5	30.0	30.9	31.3
	8H	29.8	30.7	30.3	31.1	31.5	29.7	30.6	30.2	31.0	31.4
	12H	29.9	30.7	30.4	31.1	31.6	29.8	30.6	30.3	31.0	31.5
8H	4H	29.4	30.2	29.8	30.6	31.1	29.3	30.2	29.7	30.6	31.0
	6H	30.1	30.8	30.5	31.2	31.7	30.0	30.7	30.4	31.1	31.6
	8H	30.3	31.0	30.8	31.4	31.9	30.2	30.9	30.7	31.3	31.8
	12H	30.5	31.1	31.0	31.5	32.0	30.4	30.9	30.9	31.4	31.9
12H	4H	29.4	30.2	29.8	30.6	31.0	29.3	30.1	29.8	30.5	31.0
	6H	30.1	30.8	30.6	31.2	31.7	30.0	30.7	30.5	31.1	31.6
	8H	30.4	31.0	30.9	31.4	32.0	30.3	30.9	30.8	31.3	31.9
Variations with the observer position at spacings:											
S = 1.0H	+ 0.1 / - 0.2					+ 0.1 / - 0.2					
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3					
2.0H	+ 0.2 / - 0.3					+ 0.2 / - 0.4					

CIE Pub.117, 525.0 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -2.2)

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-04

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm		
NAME: DJ602408NO	TYPE:	WEIGHT:
SPEC.:DJ602408NO-8NWNSA012WC0100	DIM.: 1000*8*1.5mm	SERIAL No.:
MFR.: COLORS	SUR.:1000*8mm	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	56	45	38	56	44	37	54	44	37	31
0.80	66	55	47	65	54	47	63	53	47	39
1.00	75	64	56	74	63	56	71	64	55	48
1.25	82	71	64	81	71	64	78	69	63	55
1.50	87	77	70	85	76	69	82	74	68	60
2.00	94	85	79	92	84	78	88	82	76	68
2.50	98	90	84	96	89	83	92	86	81	72
3.00	102	95	89	99	93	88	95	90	85	76
4.00	106	100	95	103	98	94	99	94	91	81
5.00	108	103	99	106	101	97	101	97	94	84
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-04

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm		
NAME: DJ602408NO	TYPE:	WEIGHT:
SPEC.:DJ602408NO-8NWNSA012WC0100	DIM.: 1000*8*1.5mm	SERIAL No.:
MFR.: COLORS	SUR.:1000*8mm	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-04

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

AAI Figure

Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm		
NAME: DJ602408NO	TYPE:	WEIGHT:
SPEC.:DJ602408NO-8NWNSA012WC0100	DIM.: 1000*8*1.5mm	SERIAL No.:
MFR.: COLORS	SUR.:1000*8mm	Shielding Angle:

Flux out:396.4 lm




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-04

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm		
NAME: DJ602408NO	TYPE:	WEIGHT:
SPEC.:DJ602408NO-8NWNSA012WC0100	DIM.: 1000*8*1.5mm	SERIAL No.:
MFR.: COLORS	SUR.:1000*8mm	Shielding Angle:



C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JYH
 Test Date:2020-09-04

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:10.950m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JYH
Test Date: 2020-09-04

Range: 0 - 180DEG
Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity: 65.0%
Test Distance: 10.950m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:24.00V I:0.1830A P:4.390W PF:1.000 Freq:0Hz Lamp Flux:525.024x1 lm		
NAME: DJ602408NO	TYPE:	WEIGHT:
SPEC.:DJ602408NO-8NWN5A012WC0100	DIM.: 1000*8*1.5mm	SERIAL No.:
MFR.: COLORS	SUR.:1000*8mm	Shielding Angle:

Table--1

UNIT: cd

C(DEG) g (DEG)	0	45	90	135	180	225	270	315										
0	172	172	172	172	172	172	172	172										
5	172	172	172	172	171	171	171	172										
10	170	171	170	170	169	169	169	170										
15	168	168	167	167	166	165	166	167										
20	164	164	163	163	161	161	161	162										
25	158	159	158	157	155	155	156	157										
30	152	152	151	150	148	147	149	150										
35	144	145	143	142	139	139	140	142										
40	135	135	134	133	130	129	131	132										
45	124	125	123	122	119	118	120	122										
50	112	113	112	110	107	106	108	110										
55	99.4	100	98.6	96.9	93.4	92.8	94.5	96.5										
60	85.2	86.2	84.3	82.7	79.0	78.4	80.2	82.2										
65	70.0	71.0	69.1	67.4	63.8	63.1	64.8	66.9										
70	54.0	54.9	53.0	51.4	47.9	47.3	48.9	50.9										
75	37.7	38.5	36.7	35.1	32.0	31.3	33.0	34.7										
80	22.2	22.8	21.3	19.9	17.4	16.8	18.1	19.6										
85	9.26	9.88	8.56	7.86	5.91	5.80	6.45	7.60										
90	1.71	1.84	0.86	1.20	0.55	0.47	0.15	0.83										
95	0.55	0.58	0.59	0.61	0.36	0.30	0.24	0.25										
100	0.53	0.61	0.57	0.64	0.47	0.40	0.45	0.40										
105	0.70	0.75	0.61	0.78	0.71	0.62	0.67	0.60										
110	0.93	0.94	0.82	0.95	0.94	0.81	0.89	0.83										
115	1.13	1.17	1.08	1.17	1.14	0.95	1.09	1.04										
120	1.35	1.36	1.29	1.37	1.33	1.14	1.25	1.25										
125	1.57	1.54	1.48	1.53	1.53	1.31	1.41	1.39										
130	1.77	1.69	1.62	1.68	1.71	1.48	1.54	1.52										
135	1.90	1.82	1.78	1.82	1.85	1.68	1.65	1.65										
140	2.03	1.92	1.91	1.95	1.99	1.80	1.74	1.70										
145	2.12	1.97	1.96	2.08	2.07	1.99	1.82	1.78										
150	2.21	2.04	2.05	2.24	2.16	2.14	1.94	1.80										
155	2.33	2.08	2.19	2.39	2.25	2.32	2.15	1.89										
160	2.44	2.18	2.38	2.51	2.38	2.43	2.38	2.00										
165	2.54	2.36	2.54	2.62	2.42	2.53	2.56	2.26										
170	2.58	2.59	2.74	2.74	2.39	2.65	2.74	2.53										
175	2.46	2.82	2.86	2.89	2.38	2.79	2.91	2.83										
180	2.50	2.97	2.97	3.07	2.52	2.97	3.02	3.07										

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JYH
Test Date:2020-09-04

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:10.950m [K=1.0000]
Remarks: