


## LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm		
NAME: NMT1312-Plus-EP	TYPE:	WEIGHT:
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B	DIM.: 1000*13*12	SERIAL No.:01
MFR.: COLORS	SUR.:1000*13	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 6.24 lm/W
MODEL	NMT1312-Plus-EP	I <sub>max</sub> (cd)	14.00	S/MH(C0/180)	1.28	
NOMINAL POWER(W)	6.9	LOR(%)	100.0	S/MH(C90/270)	1.23	
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	43.049	h UP,DN(C0-180)	2.1,48.6	
NOMINAL FLUX(lm)	43.049	CIE CLASS	DIRECT	h UP,DN(C180-360)	2.1,47.2	
LAMPS INSIDE	1	h up(%)	4.2	CIBSE SHR NOM	1.25	
TEST VOLTAGE(V)	24	h down(%)	95.8	CIBSE SHR MAX	1.35	

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG  
 C Interval: 45.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators: JYH  
 Test Date: 2020-03-27

Range: 0 - 180DEG  
 Interval: 1.0DEG  
 Test System: EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
 Humidity: 65.0%  
 Test Distance: 10.950m [K=1.0000]  
 Remarks:

## ZONAL FLUX DIAGRAM

### ZONAL FLUX DIAGRAM:


g	C0	C45	C90	C135	C180	C225	C270	C315	g	F zone	F total	%lum,lamp
10	13.85	13.79	13.82	13.83	13.81	13.79	13.67	13.79	0~ 10	1.327	1.327	3.08,3.08
20	13.19	13.12	13.06	13.16	13.15	13.02	12.82	13.05	10~ 20	3.809	5.136	11.9,11.9
30	12.06	11.98	11.82	12.05	12.04	11.80	11.54	11.89	20~ 30	5.780	10.92	25.4,25.4
40	10.54	10.44	10.19	10.51	10.54	10.20	9.882	10.30	30~ 40	6.978	17.89	41.6,41.6
50	8.701	8.545	8.230	8.618	8.675	8.278	7.908	8.394	40~ 50	7.259	25.15	58.4,58.4
60	6.619	6.459	6.117	6.507	6.575	6.161	5.752	6.297	50~ 60	6.603	31.75	73.8,73.8
70	4.390	4.245	3.865	4.237	4.352	3.908	3.494	4.082	60~ 70	5.146	36.90	85.7,85.7
80	2.237	2.006	1.622	2.021	2.169	1.789	1.320	1.949	70~ 80	3.125	40.03	93,93
90	0.8886	0.6204	0.2274	0.7213	0.9064	0.5819	0.0065	0.6291	80~ 90	1.210	41.24	95.8,95.8
100	0.6347	0.4273	0.0067	0.5273	0.6479	0.4475	0	0.4276	90~100	0.4879	41.72	96.9,96.9
110	0.5745	0.3072	0.0067	0.4736	0.6211	0.3875	0.0401	0.3807	100~110	0.3974	42.12	97.8,97.8
120	0.5344	0.2267	0.0067	0.3138	0.5010	0.3407	0.0668	0.3474	110~120	0.3182	42.44	98.6,98.6
130	0.4677	0.2071	0.0667	0.1937	0.4071	0.1605	0.0868	0.2539	120~130	0.2366	42.68	99.1,99.1
140	0.3680	0.1403	0.1002	0.1136	0.1870	0.1136	0.1002	0.1604	130~140	0.1548	42.83	99.5,99.5
150	0.2007	0.1469	0.1002	0.1403	0.1403	0.1136	0.1269	0.1269	140~150	0.0911	42.92	99.7,99.7
160	0.2004	0.1670	0.1002	0.1602	0.1536	0.1136	0.1603	0.1202	150~160	0.0646	42.99	99.9,99.9
170	0.1871	0.1937	0.1870	0.1871	0.1670	0.1870	0.1938	0.1202	160~170	0.0444	43.03	100,100
180	0.1870	0.2137	0.2137	0.2204	0.2004	0.2071	0.2137	0.2137	170~180	0.0184	43.05	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-03-27

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

LUMINANCE LIMITATION CURVES

Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm		
NAME: NMT1312-Plus-EP	TYPE:	WEIGHT:
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B	DIM.: 1000*13*12	SERIAL No.:01
MFR.: COLORS	SUR.:1000*13	Shielding Angle:




C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-03-27

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm		
NAME: NMT1312-Plus-EP	TYPE:	WEIGHT:
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B	DIM.: 1000*13*12	SERIAL No.:01
MFR.: COLORS	SUR.:1000*13	Shielding Angle:

r <sub>cc</sub>	80%			70%			50%			30%			10%			0
r <sub>w</sub>	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r <sub>fc</sub>	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.18	1.18	1.18	1.15	1.15	1.15	1.09	1.09	1.09	1.03	1.03	1.03	.98	.98	.98	.96
1.0	1.02	.98	.94	.90	.96	.92	.95	.91	.88	.90	.87	.85	.86	.83	.81	.79
2.0	.89	.82	.76	.87	.80	.75	.82	.77	.72	.78	.74	.70	.75	.71	.68	.65
3.0	.78	.69	.63	.76	.68	.62	.72	.66	.60	.69	.63	.59	.66	.61	.57	.55
4.0	.69	.60	.53	.67	.59	.52	.64	.57	.51	.61	.55	.50	.59	.53	.49	.47
5.0	.61	.52	.46	.60	.51	.45	.57	.50	.44	.55	.48	.43	.53	.47	.43	.40
6.0	.55	.46	.40	.54	.46	.39	.52	.44	.39	.50	.43	.38	.48	.42	.37	.35
7.0	.50	.41	.35	.49	.41	.35	.47	.40	.34	.45	.39	.34	.44	.38	.33	.31
8.0	.46	.37	.31	.45	.37	.31	.43	.36	.30	.41	.35	.30	.40	.34	.30	.28
9.0	.42	.34	.28	.41	.33	.28	.40	.32	.27	.38	.32	.27	.37	.31	.27	.25
10.0	.39	.31	.25	.38	.30	.25	.37	.30	.25	.35	.29	.25	.34	.28	.24	.22



C Range: 0 - 360DEG  
 C Interval: 45.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:JYH  
 Test Date:2020-03-27

g Range: 0 - 180DEG  
 g Interval: 1.0DEG  
 Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
 Humidity:65.0%  
 Test Distance:10.950m [K=1.0000]  
 Remarks:

### WEC AND CCEC

Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm		
NAME: NMT1312-Plus-EP	TYPE:	WEIGHT:
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B	DIM.: 1000*13*12	SERIAL No.:01
MFR.: COLORS	SUR.:1000*13	Shielding Angle:

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Wall Exitance Coefficients(WEC)												
0.0																
1.0	.321	.183	.058	.313	.178	.057	.297	.171	.054	.283	.163	.052	.269	.156	.050	
2.0	.298	.163	.050	.290	.160	.049	.276	.154	.048	.263	.148	.046	.251	.142	.045	
3.0	.273	.145	.044	.267	.143	.043	.254	.138	.042	.243	.133	.041	.232	.128	.040	
4.0	.251	.131	.038	.245	.128	.038	.234	.124	.037	.224	.120	.036	.214	.116	.035	
5.0	.232	.118	.034	.226	.116	.034	.216	.113	.033	.207	.109	.033	.198	.106	.032	
6.0	.214	.107	.031	.210	.106	.030	.201	.103	.030	.192	.100	.029	.184	.097	.029	
7.0	.199	.098	.028	.195	.097	.028	.187	.094	.027	.179	.092	.027	.172	.089	.026	
8.0	.186	.091	.026	.182	.090	.025	.175	.087	.025	.168	.085	.025	.161	.083	.024	
9.0	.174	.084	.024	.171	.083	.023	.164	.081	.023	.158	.079	.023	.152	.077	.022	
10.0	.164	.078	.022	.160	.077	.022	.154	.076	.021	.149	.074	.021	.143	.072	.021	

rcc	80%			70%			50%			30%			10%			0	
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
rfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)										
0.0	.223	.223	.223	.190	.190	.190	.130	.130	.130	.075	.075	.075	.024	.024	.024		
1.0	.213	.188	.166	.183	.162	.143	.125	.111	.099	.072	.064	.057	.023	.021	.019		
2.0	.206	.164	.130	.176	.142	.112	.121	.098	.078	.070	.057	.046	.022	.018	.015		
3.0	.198	.147	.107	.170	.127	.092	.116	.088	.065	.067	.051	.038	.022	.017	.013		
4.0	.190	.134	.091	.163	.116	.079	.112	.081	.056	.065	.047	.033	.021	.015	.011		
5.0	.183	.124	.080	.157	.107	.070	.108	.075	.049	.063	.044	.029	.020	.014	.010		
6.0	.176	.115	.072	.151	.100	.063	.104	.070	.044	.060	.041	.026	.019	.013	.009		
7.0	.169	.109	.066	.145	.094	.058	.100	.066	.041	.058	.039	.024	.019	.013	.008		
8.0	.162	.103	.062	.140	.089	.054	.097	.063	.038	.056	.037	.023	.018	.012	.008		
9.0	.156	.098	.059	.135	.085	.051	.093	.060	.036	.054	.035	.022	.018	.012	.007		
10.0	.150	.094	.056	.130	.081	.049	.090	.057	.035	.052	.034	.021	.017	.011	.007		

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-03-27

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

UGR(Unified Glare Rating) Table

Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm											
NAME: NMT1312-Plus-EP					TYPE:			WEIGHT:			
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B					DIM.: 1000*13*12			SERIAL No.:01			
MFR.: COLORS					SUR.:1000*13			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H	23.7	25.2	24.1	25.5	25.8	23.5	24.9	23.8	25.2	25.5	
	3H	25.4	26.8	25.8	27.1	27.4	25.0	26.4	25.4	26.7	27.0
	4H	26.2	27.5	26.5	27.8	28.1	25.6	26.9	26.0	27.3	27.6
	6H	26.8	28.0	27.2	28.3	28.7	26.1	27.3	26.5	27.6	28.0
	8H	27.0	28.2	27.4	28.6	28.9	26.2	27.4	26.6	27.7	28.1
	12H	27.3	28.4	27.7	28.8	29.2	26.3	27.4	26.7	27.8	28.2
4H	2H	24.3	25.6	24.7	26.0	26.3	24.1	25.4	24.5	25.8	26.1
	3H	26.2	27.4	26.6	27.7	28.1	25.9	27.0	26.3	27.4	27.8
	4H	27.1	28.1	27.5	28.5	28.9	26.6	27.7	27.1	28.1	28.5
	6H	27.8	28.8	28.3	29.2	29.6	27.2	28.1	27.7	28.5	29.0
	8H	28.2	29.0	28.7	29.5	30.0	27.4	28.2	27.9	28.7	29.2
	12H	28.5	29.3	29.0	29.8	30.2	27.5	28.3	28.0	28.8	29.3
8H	4H	27.4	28.2	27.8	28.7	29.1	27.0	27.8	27.4	28.3	28.7
	6H	28.3	29.0	28.8	29.5	30.0	27.7	28.4	28.2	28.9	29.4
	8H	28.7	29.4	29.3	29.9	30.4	28.0	28.6	28.5	29.1	29.7
	12H	29.2	29.8	29.8	30.3	30.8	28.2	28.8	28.8	29.3	29.9
12H	4H	27.4	28.2	27.9	28.6	29.1	27.0	27.8	27.5	28.3	28.7
	6H	28.4	29.0	28.9	29.5	30.0	27.8	28.4	28.3	28.9	29.5
	8H	28.9	29.4	29.4	29.9	30.5	28.2	28.7	28.7	29.2	29.8
Variations with the observer position at spacings:											
S = 1.0H	+ 0.1 / - 0.2					+ 0.2 / - 0.2					
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3					
2.0H	+ 0.1 / - 0.3					+ 0.1 / - 0.3					

CIE Pub.117, 43.05 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -10.9)

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-03-27

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

### UTILIZATION FACTORS TABLE

Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm		
NAME: NMT1312-Plus-EP	TYPE:	WEIGHT:
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B	DIM.: 1000*13*12	SERIAL No.:01
MFR.: COLORS	SUR.:1000*13	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	56	44	37	55	44	37	53	43	36	30
0.80	65	54	46	64	53	46	62	52	45	38
1.00	74	62	55	72	62	55	70	63	54	46
1.25	81	70	63	79	69	62	76	67	61	53
1.50	86	76	68	84	74	68	80	72	66	58
2.00	93	84	77	91	82	76	87	80	74	66
2.50	97	89	82	94	87	81	90	84	79	70
3.00	100	93	87	98	91	86	93	88	83	74
4.00	104	98	93	102	96	92	97	92	88	78
5.00	107	102	97	104	99	95	99	95	92	81
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-03-27

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

## ISOCANDELA DIAGRAM

Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm		
NAME: NMT1312-Plus-EP	TYPE:	WEIGHT:
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B	DIM.: 1000*13*12	SERIAL No.:01
MFR.: COLORS	SUR.:1000*13	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-03-27


Range: 0 - 180DEG  
Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:



### AAI Figure

Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm		
NAME: NMT1312-Plus-EP	TYPE:	WEIGHT:
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B	DIM.: 1000*13*12	SERIAL No.:01
MFR.: COLORS	SUR.:1000*13	Shielding Angle:

Flux out:29.25 lm




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-03-27

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

## ISOLUX DIAGRAM


Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm		
NAME: NMT1312-Plus-EP	TYPE:	WEIGHT:
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B	DIM.: 1000*13*12	SERIAL No.:01
MFR.: COLORS	SUR.:1000*13	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-03-27

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

## Planar Illuminance Curve



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: JYH  
Test Date: 2020-03-27

deg Range: 0 - 180DEG  
deg Interval: 1.0DEG  
Test System: EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity: 65.0%  
Test Distance: 10.950m [K=1.0000]  
Remarks:

## LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:24.00V I:0.2900A P:6.900W PF:1.000 Freq:0Hz Lamp Flux:43.049x1 lm		
NAME: NMT1312-Plus-EP	TYPE:	WEIGHT:
SPEC.:NMT1312-0RGBX24CDS020CC0500-Plus-EP-B	DIM.: 1000*13*12	SERIAL No.:01
MFR.: COLORS	SUR.:1000*13	Shielding Angle:

Table--1

UNIT: cd

C(DEG) g (DEG)	0	45	90	135	180	225	270	315										
0	14.0	14.0	14.0	14.0	14.0	14.0	14.0	14.0										
5	14.0	14.0	14.0	14.0	14.0	14.0	13.9	14.0										
10	13.9	13.8	13.8	13.8	13.8	13.8	13.7	13.8										
15	13.6	13.5	13.5	13.6	13.5	13.5	13.3	13.5										
20	13.2	13.1	13.1	13.2	13.1	13.0	12.8	13.1										
25	12.7	12.6	12.5	12.7	12.7	12.5	12.3	12.5										
30	12.1	12.0	11.8	12.1	12.0	11.8	11.5	11.9										
35	11.4	11.3	11.1	11.3	11.4	11.0	10.7	11.1										
40	10.5	10.4	10.2	10.5	10.5	10.2	9.88	10.3										
45	9.66	9.54	9.26	9.60	9.69	9.29	8.92	9.40										
50	8.70	8.54	8.23	8.62	8.68	8.28	7.91	8.39										
55	7.69	7.53	7.18	7.58	7.66	7.25	6.85	7.37										
60	6.62	6.46	6.12	6.51	6.58	6.16	5.75	6.30										
65	5.51	5.36	5.04	5.40	5.47	5.06	4.64	5.18										
70	4.39	4.25	3.86	4.24	4.35	3.91	3.49	4.08										
75	3.28	3.10	2.72	3.12	3.22	2.82	2.41	2.98										
80	2.24	2.01	1.62	2.02	2.17	1.79	1.32	1.95										
85	1.39	1.13	0.74	1.19	1.36	1.00	0.47	1.12										
90	0.89	0.62	0.23	0.72	0.91	0.58	0.01	0.63										
95	0.68	0.44	0.09	0.60	0.73	0.47	0.00	0.47										
100	0.63	0.43	0.01	0.53	0.65	0.45	0.00	0.43										
105	0.61	0.40	0.01	0.51	0.61	0.42	0.03	0.42										
110	0.57	0.31	0.01	0.47	0.62	0.39	0.04	0.38										
115	0.55	0.22	0.01	0.41	0.55	0.35	0.05	0.37										
120	0.53	0.23	0.01	0.31	0.50	0.34	0.07	0.35										
125	0.51	0.21	0.01	0.29	0.47	0.24	0.08	0.31										
130	0.47	0.21	0.07	0.19	0.41	0.16	0.09	0.25										
135	0.44	0.14	0.10	0.12	0.32	0.11	0.09	0.23										
140	0.37	0.14	0.10	0.11	0.19	0.11	0.10	0.16										
145	0.27	0.15	0.10	0.12	0.14	0.11	0.11	0.13										
150	0.20	0.15	0.10	0.14	0.14	0.11	0.13	0.13										
155	0.19	0.16	0.10	0.15	0.15	0.11	0.14	0.12										
160	0.20	0.17	0.10	0.16	0.15	0.11	0.16	0.12										
165	0.20	0.17	0.11	0.17	0.15	0.13	0.19	0.12										
170	0.19	0.19	0.19	0.19	0.17	0.19	0.19	0.12										
175	0.18	0.21	0.21	0.21	0.17	0.20	0.21	0.21										
180	0.19	0.21	0.21	0.22	0.20	0.21	0.21	0.21										

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2020-03-27

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks: