


## LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 70.70 lm/W			
MODEL	NMT0606	I <sub>max</sub> (cd)	170.7	S/MH(C0/180)	1.27
NOMINAL POWER(W)	7.2	LOR(%)	100.0	S/MH(C90/270)	1.25
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	505.94	h UP,DN(C0-180)	1.2,49.2
NOMINAL FLUX(lm)	505.937	CIE CLASS	DIRECT	h UP,DN(C180-360)	1.1,48.5
LAMPS INSIDE	1	h up(%)	2.3	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	24	h down(%)	97.7	CIBSE SHR MAX	1.35



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01

Range: 0 - 180DEG  
Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

## ZONAL FLUX DIAGRAM

### ZONAL FLUX DIAGRAM:


g	C0	C45	C90	C135	C180	C225	C270	C315	g	F zone	F total	%lum,lamp
10	167.9	167.8	167.1	167.2	167.6	167.1	166.8	167.0	0- 10	16.12	16.12	3.19,3.19
20	159.3	159.0	157.8	158.1	158.6	157.7	157.4	157.9	10- 20	46.14	62.25	12.3,12.3
30	145.5	144.8	142.9	143.6	144.3	142.8	142.4	143.5	20- 30	69.87	132.1	26.1,26.1
40	127.1	126.1	123.4	124.4	125.3	123.5	122.9	124.6	30- 40	84.27	216.4	42.8,42.8
50	104.9	103.5	100.3	101.4	102.5	100.4	99.86	102.0	40- 50	87.67	304.1	60.1,60.1
60	79.78	78.06	74.22	75.44	76.59	74.43	73.93	76.75	50- 60	79.81	383.9	75.9,75.9
70	52.61	50.62	46.03	47.46	48.79	46.53	45.89	49.39	60- 70	61.75	445.6	88.1,88.1
80	25.56	23.31	18.11	20.36	22.30	19.78	18.22	22.43	70- 80	36.43	482.1	95.3,95.3
90	7.310	4.985	0.7858	4.623	6.658	4.267	0.5892	4.456	80- 90	12.26	494.3	97.7,97.7
100	2.712	1.641	0.5478	2.448	3.712	2.246	0.3617	1.008	90-100	2.834	497.2	98.3,98.3
110	1.826	1.096	0.7481	1.354	2.760	1.217	0.7752	0.9416	100-110	1.674	498.8	98.6,98.6
120	1.550	1.370	1.195	1.397	1.583	1.129	1.102	1.182	110-120	1.276	500.1	98.8,98.8
130	1.777	1.704	1.548	1.677	1.724	1.456	1.370	1.476	120-130	1.301	501.4	99.1,99.1
140	2.109	1.944	1.797	1.944	2.011	1.788	1.590	1.682	130-140	1.333	502.7	99.4,99.4
150	2.317	2.065	2.017	2.205	2.211	2.096	1.811	1.783	140-150	1.228	504.0	99.6,99.6
160	2.537	2.218	2.337	2.505	2.438	2.450	2.245	1.970	150-160	1.010	505.0	99.8,99.8
170	2.645	2.552	2.692	2.746	2.438	2.645	2.692	2.458	160-170	0.6980	505.7	99.9,99.9
180	2.552	2.992	2.986	3.006	2.565	2.992	3.006	2.992	170-180	0.2576	505.9	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
 C Interval: 45.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:JYH  
 Test Date:2021-02-01

g Range: 0 - 180DEG  
 Interval: 1.0DEG  
 Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
 Humidity:65.0%  
 Test Distance:10.950m [K=1.0000]  
 Remarks:

### LUMINANCE LIMITATION CURVES

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:



LUMINANCE cd/(m2)		
G(180)	C0/180	C90/270
85	2781	1276
80	2453	1738
75	2494	2041
70	2564	2243
65	2617	2379
60	2659	2474
55	2693	2542
50	2720	2600
45	2745	2646


C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

## CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:

r <sub>cc</sub>	80%			70%			50%			30%			10%			0
r <sub>w</sub>	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r <sub>fc</sub>	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio                      Coefficients of Utilization(CU)															
0.0	1.19	1.19	1.19	1.15	1.15	1.15	1.10	1.10	1.10	1.05	1.05	1.05	.00	.00	.00	.98
1.0	1.03	.99	.95	1.00	.96	.93	.96	.92	.89	.91	.89	.86	.87	.85	.83	.81
2.0	.89	.83	.77	.87	.81	.76	.83	.78	.73	.80	.75	.71	.76	.73	.69	.67
3.0	.78	.70	.64	.77	.69	.63	.73	.67	.61	.70	.65	.60	.67	.63	.59	.56
4.0	.69	.60	.54	.68	.60	.53	.65	.58	.52	.62	.56	.51	.60	.55	.50	.48
5.0	.62	.53	.46	.61	.52	.46	.58	.51	.45	.56	.49	.44	.54	.48	.44	.41
6.0	.56	.47	.40	.55	.46	.40	.53	.45	.39	.51	.44	.39	.49	.43	.38	.36
7.0	.50	.42	.35	.50	.41	.35	.48	.40	.35	.46	.39	.34	.45	.39	.34	.32
8.0	.46	.37	.32	.45	.37	.31	.44	.36	.31	.42	.36	.31	.41	.35	.30	.28
9.0	.42	.34	.28	.42	.34	.28	.40	.33	.28	.39	.32	.28	.38	.32	.27	.26
10.0	.39	.31	.26	.38	.31	.26	.37	.30	.25	.36	.30	.25	.35	.29	.25	.23



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

WEC AND CCEC

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Wall Exitance Coefficients(WEC)															
0.0																
1.0	.317	.180	.057	.309	.176	.056	.295	.169	.054	.281	.162	.052	.269	.156	.050	
2.0	.296	.162	.050	.289	.159	.049	.276	.153	.048	.264	.148	.046	.253	.143	.045	
3.0	.272	.145	.043	.266	.143	.043	.255	.138	.042	.244	.134	.041	.234	.130	.040	
4.0	.251	.130	.038	.245	.128	.038	.235	.125	.037	.226	.121	.037	.217	.118	.036	
5.0	.231	.118	.034	.227	.116	.034	.217	.113	.033	.209	.110	.033	.201	.107	.032	
6.0	.214	.107	.031	.210	.106	.031	.202	.103	.030	.194	.101	.030	.187	.098	.029	
7.0	.199	.099	.028	.195	.097	.028	.188	.095	.027	.181	.093	.027	.175	.091	.027	
8.0	.186	.091	.026	.183	.090	.025	.176	.088	.025	.170	.086	.025	.164	.084	.024	
9.0	.174	.084	.024	.171	.083	.023	.165	.082	.023	.159	.080	.023	.154	.078	.023	
10.0	.164	.079	.022	.161	.078	.022	.155	.076	.021	.150	.075	.021	.145	.073	.021	

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Ceiling Cavity Exitance Coefficients(CCEC)															
0.0	.208	.208	.208	.178	.178	.178	.121	.121	.121	.070	.070	.070	.022	.022	.022	
1.0	.198	.174	.151	.170	.149	.130	.116	.103	.090	.067	.059	.052	.021	.019	.017	
2.0	.191	.150	.115	.163	.129	.100	.112	.089	.070	.064	.052	.041	.021	.017	.013	
3.0	.183	.132	.092	.157	.114	.080	.108	.079	.056	.062	.046	.033	.020	.015	.011	
4.0	.175	.119	.076	.150	.103	.066	.103	.072	.046	.060	.042	.028	.019	.014	.009	
5.0	.168	.109	.065	.144	.094	.057	.099	.066	.040	.057	.039	.024	.019	.013	.008	
6.0	.161	.100	.057	.138	.087	.050	.095	.061	.035	.055	.036	.021	.018	.012	.007	
7.0	.154	.093	.051	.132	.081	.045	.091	.057	.032	.053	.033	.019	.017	.011	.006	
8.0	.147	.088	.047	.127	.076	.041	.088	.053	.029	.051	.031	.017	.017	.010	.006	
9.0	.141	.083	.043	.122	.072	.038	.084	.050	.027	.049	.030	.016	.016	.010	.005	
10.0	.135	.078	.041	.117	.068	.035	.081	.048	.025	.047	.028	.015	.015	.009	.005	

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

UGR(Unified Glare Rating) Table

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm										
NAME: NTT0606					TYPE:			WEIGHT:		
SPEC.:NTT0606-9DW24CSN050CC0100					DIM.: 1000*06*06mm			SERIAL No.:01		
MFR.: COLORS					SUR.:1000*06			Shielding Angle:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	18.7	20.2	19.0	20.4	20.6	18.4	19.9	18.7	20.1	20.4
3H	20.3	21.7	20.7	22.0	22.3	19.9	21.3	20.2	21.6	21.9
4H	21.0	22.3	21.4	22.6	22.9	20.5	21.8	20.8	22.1	22.4
6H	21.6	22.8	22.0	23.2	23.5	20.9	22.1	21.3	22.4	22.8
8H	21.8	23.0	22.2	23.4	23.7	21.0	22.2	21.4	22.5	22.9
12H	22.0	23.2	22.4	23.5	23.9	21.0	22.2	21.4	22.5	22.9
4H 2H	19.3	20.6	19.6	20.9	21.2	19.1	20.4	19.4	20.7	21.0
3H	21.1	22.3	21.5	22.6	23.0	20.8	21.9	21.2	22.3	22.6
4H	22.0	23.0	22.4	23.4	23.8	21.5	22.5	21.9	22.9	23.3
6H	22.7	23.6	23.1	24.0	24.4	22.0	22.9	22.4	23.3	23.8
8H	23.0	23.8	23.4	24.2	24.7	22.2	23.0	22.6	23.4	23.9
12H	23.2	24.0	23.7	24.5	24.9	22.2	23.1	22.7	23.5	23.9
8H 4H	22.2	23.1	22.7	23.5	24.0	21.8	22.7	22.3	23.1	23.5
6H	23.1	23.8	23.6	24.3	24.8	22.5	23.2	23.0	23.7	24.2
8H	23.5	24.2	24.0	24.6	25.1	22.8	23.4	23.3	23.9	24.4
12H	23.9	24.5	24.4	24.9	25.5	22.9	23.5	23.4	24.0	24.5
12H 4H	22.2	23.0	22.7	23.5	23.9	21.9	22.7	22.3	23.1	23.5
6H	23.2	23.8	23.7	24.3	24.8	22.6	23.2	23.1	23.7	24.2
8H	23.6	24.2	24.1	24.7	25.2	22.9	23.5	23.4	23.9	24.5
Variations with the observer position at spacings:										
S = 1.0H	+ 0.1 / - 0.2					+ 0.1 / - 0.2				
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3				
2.0H	+ 0.1 / - 0.3					+ 0.2 / - 0.3				

CIE Pub.117, 505.9 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -2.4)

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

## UTILIZATION FACTORS TABLE

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	56	45	38	56	44	38	54	44	37	31
0.80	66	55	47	65	54	47	63	53	46	39
1.00	75	63	56	73	63	56	71	64	55	48
1.25	82	71	64	80	70	63	77	69	62	55
1.50	87	77	70	85	76	69	82	74	68	60
2.00	94	85	78	92	84	77	88	81	76	67
2.50	98	90	83	95	88	82	91	85	80	71
3.00	101	94	88	99	92	87	94	89	85	76
4.00	105	99	94	103	97	93	98	94	90	80
5.00	108	103	98	105	100	97	100	96	93	83
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

## ISOCANDELA DIAGRAM

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01


Range: 0 - 180DEG  
Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:



### AAI Figure

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:

Flux out:353.6 lm




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: JYH  
Test Date: 2021-02-01

g Range: 0 - 180DEG  
Interval: 1.0DEG  
Test System: EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity: 65.0%  
Test Distance: 10.950m [K=1.0000]  
Remarks:

### ISOLUX DIAGRAM

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

### LED Avg.L Report

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	2547
L_0~180(75)av	2372
L_0~180(85)av	2584
L_90~270(65)av	2373
L_90~270(75)av	2041
L_90~270(85)av	1323
L_45(65)av	2465
L_45(75)av	2223
L_45(85)av	2063

Standard: GB/T 29293-2012

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks:

### Planar Illuminance Curve



C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: JYH  
Test Date: 2021-02-01

deg Range: 0 - 180DEG  
Interval: 1.0DEG  
Test System: EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity: 65.0%  
Test Distance: 10.950m [K=1.0000]  
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:24.00V I:0.2982A P:7.156W PF:1.000 Freq:0Hz Lamp Flux:505.937x1 lm		
NAME: NTT0606	TYPE:	WEIGHT:
SPEC.:NTT0606-9DW24CSN050CC0100	DIM.: 1000*06*06mm	SERIAL No.:01
MFR.: COLORS	SUR.:1000*06	Shielding Angle:

Table--1

UNIT: cd

C(DEG) g (DEG)	0	45	90	135	180	225	270	315										
0	171	171	170	170	171	171	170	170										
5	170	170	169	169	170	170	169	169										
10	168	168	167	167	168	167	167	167										
15	164	164	163	163	164	163	163	163										
20	159	159	158	158	159	158	157	158										
25	153	153	151	152	152	151	151	151										
30	146	145	143	144	144	143	142	143										
35	137	136	134	135	135	134	133	135										
40	127	126	123	124	125	123	123	125										
45	116	115	112	113	114	112	112	114										
50	105	103	100	101	102	100	99.9	102										
55	92.7	91.1	87.5	88.7	89.9	87.7	87.2	89.7										
60	79.8	78.1	74.2	75.4	76.6	74.4	73.9	76.8										
65	66.4	64.5	60.3	61.6	62.8	60.6	60.0	63.2										
70	52.6	50.6	46.0	47.5	48.8	46.5	45.9	49.4										
75	38.7	36.6	31.7	33.4	34.9	32.6	31.7	35.5										
80	25.6	23.3	18.1	20.4	22.3	19.8	18.2	22.4										
85	14.5	12.0	6.67	10.1	12.5	9.74	7.16	11.3										
90	7.31	4.98	0.79	4.62	6.66	4.27	0.59	4.46										
95	3.89	2.33	0.57	2.97	4.42	2.71	0.20	1.97										
100	2.71	1.64	0.55	2.45	3.71	2.25	0.36	1.01										
105	2.28	1.22	0.57	1.88	3.30	1.75	0.59	1.00										
110	1.83	1.10	0.75	1.35	2.76	1.22	0.78	0.94										
115	1.56	1.20	0.99	1.30	2.02	1.08	0.96	1.04										
120	1.55	1.37	1.19	1.40	1.58	1.13	1.10	1.18										
125	1.62	1.54	1.37	1.54	1.63	1.26	1.24	1.38										
130	1.78	1.70	1.55	1.68	1.72	1.46	1.37	1.48										
135	1.94	1.84	1.68	1.82	1.87	1.59	1.50	1.57										
140	2.11	1.94	1.80	1.94	2.01	1.79	1.59	1.68										
145	2.23	2.02	1.91	2.07	2.12	1.91	1.68	1.72										
150	2.32	2.06	2.02	2.20	2.21	2.10	1.81	1.78										
155	2.44	2.15	2.15	2.37	2.33	2.25	2.02	1.82										
160	2.54	2.22	2.34	2.51	2.44	2.45	2.24	1.97										
165	2.58	2.36	2.53	2.63	2.51	2.54	2.48	2.22										
170	2.65	2.55	2.69	2.75	2.44	2.65	2.69	2.46										
175	2.54	2.78	2.87	2.90	2.42	2.79	2.89	2.76										
180	2.55	2.99	2.99	3.01	2.56	2.99	3.01	2.99										

C Range: 0 - 360DEG  
C Interval: 45.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:JYH  
Test Date:2021-02-01

g Range: 0 - 180DEG  
g Interval: 1.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.0.362  
Humidity:65.0%  
Test Distance:10.950m [K=1.0000]  
Remarks: